

THE KROGER COMPANY

N-273

DRAWING INDEX

T0.0	COVER SHEET
T1.1	PROPOSED CABLE ROUTING & ZONE COVERAGE
T1.2	LOSS PREVENTION CAMERA LAYOUT
T1.3	OVERALL STORE JACK LOCATIONS
T1.3.1	ER-E (EQUIPMENT ROOM) JACK LOCATIONS
T1.3.2	TR-B (BACK ROOM) JACK LOCATIONS
T4.2	TR-B (CHANGE OUT CABINET NO DRAWING)
T5.1	TELECOMMUNICATION LABELING & FIRE STOP DETAIL
T6.2	TELECOMMUNICATION CABLE SCHEDULE EXCEL

CAMERA LOCATIONS



AXIS P3224-V MKII-
ONE (1) CATEGORY 5E, 4-PAIR,
UTP CABLE MOUNTED AS
REQUIRED FOR FIXED CAMERA
DEVICE. (25-FT SERVICE LOOP
REQUIRED AT DEVICE LOCATION).



AXIS P3375-VE-
ONE (1) CATEGORY 5E, 4-PAIR,
UTP CABLE MOUNTED AS
REQUIRED FOR FIXED CAMERA
DEVICE. (25-FT SERVICE LOOP
REQUIRED AT DEVICE LOCATION).



AXIS P5624-E MKII-
ONE (1) CATEGORY 5E, 4-PAIR,
UTP CABLE MOUNTED AS
REQUIRED FOR FIXED CAMERA
DEVICE. (25-FT SERVICE LOOP
REQUIRED AT DEVICE LOCATION).



DOORJAM CAM (P1214)-
ONE (1) CATEGORY 5E, 4-PAIR,
UTP CABLE MOUNTED AS
REQUIRED FOR DOOR JAM
DEVICE. (25-FT SERVICE LOOP
REQUIRED AT DEVICE LOCATION).



SECO-LARM (W/AXIS M7011)-
ONE (1) CATEGORY 5E, 4-PAIR,
UTP CABLE MOUNTED AS
REQUIRED FOR COVERT CAMERA
DEVICE. (25-FT SERVICE LOOP
REQUIRED AT DEVICE LOCATION).



AXIS M5525-E PTZ -
ONE (1) CATEGORY 5E, 4-PAIR,
UTP CABLE MOUNTED AS
REQUIRED FOR PTZ CAMERA
DEVICE. (25-FT SERVICE LOOP
REQUIRED AT DEVICE LOCATION).
**USE AXIS Q6042 FOR LONGER
RANGE.**



PTZ BY PVM CAMERA (P1214) - TWO (2)
CATEGORY 5E, 4-PAIR, UTP
CABLES. MOUNTED AS REQUIRED.



10" EPVM W/CAMERA - TWO (2)
CATEGORY 5E, 4-PAIR, UTP
CABLES MOUNTED AS REQUIRED.


PATHWAYS AND SPACES

	PROPOSED FIBER OPTIC BACKBONE ROUTING
	PROPOSED RISER COPPER BACKBONE ROUTING
	PROPOSED CABLE TRAY ROUTING


ER-E & TR ZONE COVERAGE



ER-E ZONE AREA



TR-P (PHARMACY) ZONE AREA



TR-B (BACK ROOM) ZONE AREA



TR-M (MEAT COOLER) ZONE AREA



TR-L (SECURITY) ZONE AREA



TR-X (XXXXXX) ZONE AREA

PAGING

	OPEN BEAM SPEAKER SET/TAPPED TO 1 WATT
	CEILING SPEAKER SET/TAPPED TO 1 WATT
	CSD 2X2 SET TO 1 WATT
	AT10A
	MD8TSL TAPPED TO 1 WATT
	SPT15A SET TO TAP #3 (3.8 WATTS)

TELECOMMUNICATIONS SYMBOLS

WORK AREA LOCATIONS

	ONE (1) CATEGORY 5E, 4-PAIR, UTP CABLE MOUNTED AS REQUIRED
	TWO (2) CATEGORY 5E, 4-PAIR, UTP CABLES MOUNTED AS REQUIRED
	THREE (3) CATEGORY 5E, 4-PAIR, UTP CABLES MOUNTED AS REQUIRED
	FOUR (4) CATEGORY 5E, 4-PAIR, UTP CABLES MOUNTED AS REQUIRED
	FIVE (5) CATEGORY 5E, 4-PAIR, UTP CABLES MOUNTED AS REQUIRED
	SIX (6) CATEGORY 5E, 4-PAIR, UTP CABLES MOUNTED AS REQUIRED
	TWO (2) CATEGORY 5E, 4-PAIR, UTP CABLES FOR QUE VISION MONITORS AND THIN CLIENT. (TO BE INSTALLED AND MAINTAINED BY OTHERS)
	ONE (1) CATEGORY 6, 4-PAIR, UTP CABLE TERMINATED IN A SINGLE PORT BISCUIT MOUNTED AT CEILING HEIGHT WITH A 20-FOOT SERVICE LOOP FOR ZAP MOUNTING W=WIRELESS AP AT LOCATION Z=ZAP AT LOCATION #=AP SEQUENCE NUMBERING (GA/SA IS FOR KROGER USE ONLY)
	ONE (1) CATEGORY 6, 4-PAIR, UTP CABLE MOUNTED AS REQUIRED FOR A FREEZER WIRELESS ACCESS POINT. SEE DETAIL ON SHEET T1.6.3
	Z# =(1) CATEGORY 6, 4-PAIR MOUNTED IN A SINGLE PORT BISCUIT IN A 8"X8"X4" BOX INSIDE THE FREEZER/PREP AREA.
	Z4# =(2) CATEGORY 6, 4-PAIR MOUNTED IN A 2-PORT BISCUIT IN A 8"X8"X4" BOX INSIDE THE FREEZER/PREP AREA. SEE DETAIL ON SHEET T1.6.3
	ONE (1) CATEGORY 6, 4-PAIR, UTP CABLE MOUNTED AS REQUIRED FOR AN OUTSIDE WIRELESS ACCESS POINT. SEE DETAIL ON SHEET T1.6.3



NOTE: DRAWING IS INTENDED ONLY TO SHOW THE REQUIREMENTS OF THE ORDER CO. THE EXISTENCE OF THE BUILDING IS ASSUMED TO BE ACCORDING TO ALL APPLICABLE PLANNING, ZONING, AND BUILDING CODES. THE USER OF THIS DRAWING IS RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS. THE USER OF THIS DRAWING IS RESPONSIBLE FOR THE ACCURACY OF THE INFORMATION PROVIDED BY THE OWNER.

COLUMBUS
(NEW) ARTISAN

4111 EXECUTIVE PARKWAY
WESTERVILLE, OH
PHONE: (614) 898-3341
FAX: (614) 898-3377



GENERAL OFFICE
FACILITY ENGINEERING
100 WINE ST. CINCINNATI, OH 45202
PH: 513.763.7600

WITHIN THE WALLS
N-273
60 WORTHINGTON MALL
WORTHINGTON, OH

CURRENT PLAN DATE:	11/8/2019
ORIGINAL PLAN DATE:	6/14/2019
DRAWN:	J. EDWARDS
CHECKED:	D. BUSAM
REVISIONS:	
STANDARD PLOTTED SCALE:	NONE
BUILDING STATS:	
TOTAL SHELVING:	2199 LF
SALES AREA:	36,054 SF
3" X 6" JARS BAKING:	60 SF
BASE STORE:	53,086 SF
MEDZANNE:	2,093 SF
DOCK / UTILITY:	1,564 SF
GROSS BUILDING:	57,603 SF
COVER SHEET	
ITBELL PACKAGE D:	Not Applicable
SHEET:	N-273 T0.0
CAD FILE:	