© 2019 Moody•Nolan, Inc.




NOTES:

1. FOR CASES THAT DO NOT HAVE A REMOVABLE REAR CASE TRIM, ATTACH THE FLASHING TO THE BACK OF THE CASE AND CAULK ALONG THE TOP.
2. CUT 1/4" WIDE GROOVE FOR FLASHING PARALLEL TO THE REAR OF CASES TO ENSURE PROPER INSTALLATION.
3. WHERE FLASHING PIECES BUTT TOGETHER CAULK JOINT WITH SILVER SILICONE ENTIRE LENGTH OF JOINT EXPOSED.
4. CAULK JOINT WHERE FLASHING SETS IN RESINOUS FLOOR JOINT WITH POLYUREA CAULK TO MATCH FLOOR COLOR.

| STAINLESS STEEL WATER CUT OFF FLASHING | DATE: 7/14/15 |
|---|---|
| | SCALE: NONE |
| | DRAWN: ZAW/TMW |
| MASTER INSTALLATION DETAIL | GISD—14 |

ORIGINAL ISSUE DATE 10/11/12




NOTES:

1. 6 MIL FIRE RETARDANT (MTA 701) POLYETHYLENE SHEETING DUST BARRIER — USE WHITE, CLEAR OR FROSTED/TRANSLUCENT SHEETING ONLY. BLACK SHEETING IS NOT ACCEPTABLE. WHITE TAPE FULL LENGTH OF JOINT, SECURELY ATTACH TO STRIKER BACK OF SHELVING OR 2" x 4" WOOD BRACE BARRICADE, AND EXTEND UP TO ROOF DECK AS INDICATED.
2. 2" x 4" WOOD BRACED BARRICADE 6'-0" HIGH, PROVIDE BALLAST ON BOTTOM BRACE TO SECURE. USE CONCRETE BLOCKS, SAND BAGS, BALLAST = 1A = CONCRETE BLOCKS, SANDBAGS, OR MISCELLANEOUS CONSTRUCTION MATERIALS. BALLAST & HOOKERS SHALL BE ON THE WORK AREA SIDE AND NOT ON THE CUSTOMER ACCESS SIDE.
3. ANY PORTION OF THE SPRINKLER SYSTEM WHICH BECOMES EXPOSED TO POSSIBLE FREEZING TEMPERATURES MUST BE PROTECTED FROM FREEZING WITH HEAT TAPE & INSULATION.

| TEMPORARY CONSTRUCTION BARRIERS | DATE: 7/31/19 |
|---|---|
| | SCALE: NONE |
| | DRAWN: DS/JO/ZW |
| MASTER SPECIFICATION DETAIL | ASD—162A |

ORIGINAL ISSUE DATE 6/1/07




NOTES:

1. DESIGNED FOR USE WITH GLASS DOOR END CASES. CASE CORNER GUARD, REFER TO SECTION 11 41 13 PARAGRAPH 2.2 B GENERAL STORE FIXTURE INSTALLATION IN SPECIFICATIONS. REFER TO FIXTURE PLAN FOR QUANTITY AND LOCATIONS.
2. CASE CORNER GUARD TO BE INSTALLED, AFTER CASE HAS BEEN SET. INSTALL CASE GUARD AS CLOSE TO CASE AS POSSIBLE PER MANUFACTURER'S INSTALLATION INSTRUCTIONS.

Note:
Detail Based On Installation Instructions From National Cart Co. 505000.
Legend Number GBASCG. Height 12".

| GLASS DOOR END CASE CORNER GUARD | DATE: 6/5/15 |
|---|---|
| | SCALE: NONE |
| | DRAWN: ZAW |
| MASTER SPECIFICATION DETAIL | ASD—160A |

ORIGINAL ISSUE DATE 6/5/15




NOTES:

1. DESIGNED FOR USE WITH ISLAND REFRIGERATED CASES (WITH STRAIGHT FRONTS) IN DAIRY, MEAT, SEAFOOD AND DELI DEPARTMENTS. CASE CORNER GUARD, REFER TO SECTION 11 41 13 PARAGRAPH 2.2 B GENERAL STORE FIXTURE INSTALLATION IN SPECIFICATIONS. REFER TO FIXTURE PLAN FOR QUANTITY AND LOCATIONS.
2. CASE CORNER GUARD TO BE INSTALLED, AFTER CASE HAS BEEN SET. INSTALL CASE GUARD (AND FLANGE EXTENSION) AS CLOSE TO CASE AS POSSIBLE PER MANUFACTURER'S INSTALLATION INSTRUCTIONS.
3. MAXIMUM 1" PER MANUFACTURER'S INSTALLATION INSTRUCTIONS.
4. FOR CASES WITH SHALLOW TOE KICK IT MAY BE NECESSARY TO FIELD CUT FLANGE FOR PROPER POSITIONING OF GUARD.

Note:
Detail Based On Installation From National Cart Co. 6525/5025 (50/60cm And 505000).

| REFRIGERATED CASE CORNER GUARD | DATE: 6/5/15 |
|---|---|
| | SCALE: NONE |
| | DRAWN: ZAW |
| MASTER SPECIFICATION DETAIL | ASD—160 |

ORIGINAL ISSUE DATE 7/8/06




NOTES:

1. SQUARE COLUMN COVERS ARE PREFABRICATED OWNER SUPPLIED AND CONTRACTOR INSTALLED, BECAUSE ROUND COLUMN COVERS ARE FIELD FABRICATED, REFER TO SPECIFICATIONS FOR FABRICATION. COLUMN COVERS FROM OWNER SUPPLIED 48" x 108" SHEETS OF FINISHED STEEL. REFER TO DIVISION 01 FOR COLOR AND FINISH.
2. ALL COLUMN COVERS TO BE 4'-0" HIGH, OR MATCH HEIGHT OF EXISTING WRAPPED COLUMNS.
3. AFTER COVERS HAVE BEEN INSTALLED CONTRACTOR TO CAULK A CONTINUOUS BEAD OF CLEAR PAINTABLE SILICONE SEALANT AROUND TOP AND BOTTOM OF COVERS TO SECURE IN PLACE.
4. HOLES ON THE COLUMN COVERS ARE FROM THE MANUFACTURER, USED FOR PAINTING PURPOSES. COLUMN COVERS SHOULD BE INSTALLED WITH THE HOLES DOWNWARDS TOWARDS THE FLOOR.




NOTES:

1. SEE KROGER STANDARD SPECIFICATIONS FOR ADDITIONAL INFORMATION.
2. SUPPLY AIR & RETURN AIR OPENINGS IN CURB VARY, REFER TO HSD-1 SERIES OF DETAILS FOR CURB PLACEMENT FOR CABINET SIZE.
3. SEE KROGER STANDARD SPECIFICATIONS AND DETAILS HSD-1 & HSD-2 FOR ADDITIONAL INFORMATION.
4. WHERE CURB CROSSES JOISTS AT A LOCATION GREATER THAN 4" FROM THE EDGE OF THE JOIST, ADD 2x4 BLOCKING FOR SUPPORT OF NON-BEARING LOADS NOT AT JOIST PANEL POINTS.
5. ALTERNATIVELY FASTEN CURBS TO SUPPORTING STEEL STRUCTURE USING #12 INTERCOUP SELF DRILLING SCREWS @ 12" O.C. MAX. SPACING ALONG EACH SHORT SIDE AND @ 24" O.C. MAX. SPACING ALONG EACH LONG SIDE.
6. REFERENCE ROOFING DETAILS ASD-85C & ASD-86C FOR ROOF FLASHING.

-- INSTALLATION SEQUENCE:
1. SET STRUCTURAL STEEL JOIST.
2. INSTALL PREFABRICATED CURB.
3. INSTALL ROOF DECK.
4. INSTALL INSULATION AND ROOFING.
5. PAINT STRUCTURAL STEEL & DECK TO MATCH EXISTING FOR EXPANSION MODULES.

ORIGINAL ISSUE DATE 2/20/06


ATTACH ROOF DECK TO WOOD BLOCKING WITH #12 x 1 1/2 SELF DRILLING SCREWS AT 12" O.C.
CURB
TREATED WOOD BLOCKING IN NEED OF ENTIRE LENGTH OF BASE PLATE, TO ATTACH ROOF DECK.
Detail 'A'
High Flute Installation:
ROOF JOIST — JOIST AND CURB PLACEMENT VARY, SEE NOTE No. 4. REFER TO STRUCTURAL DRAWINGS AND HSD-1 SERIES OF DETAILS FOR LOCATIONS.
CURB
CURB BASE — PLATE FLANGE SEE NOTE No. 6.
Partial Plan
Cross Section Elevation
Low Flute Installation:
See Detail 'A' for High Flute Installation.
ROOF TOP A.C. UNIT (RTU) REQUIRING CURB, SEE STRUCTURAL PLANS.
GASKET
WIND/SEISMIC RESTRAINT BRACKET AS FOLLOWS: (SEE BRACKETS — (4) BRACKETS 18 GA. LONG SIDE OF CURB EQUALLY SPACED. REFER TO MECHANICAL SPECIFICATION, ATTACH WITH SCREWS SUPPLIED BY CURB MANUFACTURER.
FALL PROTECTION/SECURITY CABLE SYSTEM, SEE STRUCT. DWGS.
CONTINUE ROOFING MEMBRANE UP CURB AND TERMINATE UNDER RTU FLASHING.
SINGLE PLY ROOF MEMBRANE OVER RIGID INSULATION PER ROOFING SPECIFICATIONS.
10" MINIMUM HIGH PREFABRICATED INSULATED STRUCTURAL CURB — ADJUSTABLE OR SLOPED, BOTH PRE-PAINTED, SEE NOTE No. 6.
SEE NOTE No. 3
SEE NOTE No. 7
SEE NOTE No. 4
SEE NOTE No. 4
Note:
This Detail is for Single Ply Membrane Roof System, See Note No. 6.

NOTES:

1. SEE KROGER STANDARD SPECIFICATIONS FOR ADDITIONAL INFORMATION.
2. SUPPLY AIR & RETURN AIR OPENINGS IN CURB VARY, REFER TO HSD-1 SERIES OF DETAILS FOR CURB PLACEMENT FOR CABINET SIZE.
3. SEE KROGER STANDARD SPECIFICATIONS AND DETAILS HSD-1 & HSD-2 FOR ADDITIONAL INFORMATION.
4. WHERE CURB CROSSES JOISTS AT A LOCATION GREATER THAN 4" FROM THE EDGE OF THE JOIST, ADD 2x4 BLOCKING FOR SUPPORT OF NON-BEARING LOADS NOT AT JOIST PANEL POINTS.
5. ALTERNATIVELY FASTEN CURBS TO SUPPORTING STEEL STRUCTURE USING #12 INTERCOUP SELF DRILLING SCREWS @ 12" O.C. MAX. SPACING ALONG EACH SHORT SIDE AND @ 24" O.C. MAX. SPACING ALONG EACH LONG SIDE.
6. REFERENCE ROOFING DETAILS ASD-85C & ASD-86C FOR ROOF FLASHING.
7. ATTACH ROOF DECK TO CURB BASE PLATE FLANGE, THRU LOW FLUTES, APPROX 12" O.C. ON ALL SIDES.
8. PREFABRICATED CURB COMES IN TWO MODELS — ADJUSTABLE AND SLOPED BASED ON RTU INSTALLED, AS FOLLOWS:
ADJUSTABLE CURB — TWO PIECES, CURB & CURB BASE PLATE INSTALL CURB INTO BASE PLATE AND SECURE WITH SCREWS SUPPLIED WITH CURB.
SLOPED CURB — ONE PIECE STRUCTURAL, PRE-SLOPED, 15" BOX ONLY.
9. NEW STORE CONSTRUCTION TO REMAIN UNPAINTED, PAINT TO MATCH EXISTING FOR EXPANSION MODULES. PROTECT FROM PAINT FROM GETTING INSIDE, RTU, PROTECT WITH PLASTIC FILM. REMOVE PLASTIC AFTER THE DECK IS PAINTED.

-- INSTALLATION SEQUENCE:
1. SET STRUCTURAL STEEL JOIST.
2. INSTALL PREFABRICATED CURB.
3. INSTALL ROOF DECK.
4. INSTALL INSULATION AND ROOFING.
5. PAINT STRUCTURAL STEEL & DECK TO MATCH EXISTING FOR EXPANSION MODULES.

ORIGINAL ISSUE DATE 2/20/06

| PREFABRICATED RTU CURB | DATE: 11/10/16 |
|---|---|
| | SCALE: NONE |
| | DRAWN: ZAW |
| MASTER SPECIFICATION DETAIL | ASD—78 |




NOTES

1. ALL CHANNEL IS COOPER B-LINE STRUT SYSTEMS B22H SLOTTED CHANNEL.
2. COOPER B-LINE STRUT SYSTEMS B133 FOUR HOLE TEE PLATE.
3. COOPER B-LINE STRUT SYSTEMS B207 FOUR HOLE OFFSET BENT TEE PLATE.
4. IF THREADED RODS ARE NOT FULL LENGTH USE JAMB NUTS ON BOTH SIDES OF COUPLER.
5. IF THREADED RODS CANNOT BE CONNECTED AT SAW CUT TOP CHORD, SPAN (3) SAW JOISTS MAXIMUM.
6. ADJUST ANGLE OF MONITOR FOR BEST VIEW OF DISPLAY.
7. ATTACHMENTS CAN BE MADE TO EITHER TOP CHORD OF SAW OR RUNNING FLOORING. DRAWING SHOWS TOP CHORD ATTACHMENT OF UNISTRUT TO ROOF METAL DECKING WILL NOT BE PERMITTED

K—0056897 48" MONITOR
K—0053656 MOUNTING KIT

| DELI MONITOR MOUNTING | DATE: 9/8/16 |
|---|---|
| | SCALE: NONE |
| | DRAWN: TMW |
| MASTER SPECIFICATION DETAIL | ASD—72 |

ORIGINAL ISSUE DATE 9/8/16




Notes:

IF ANY SIDE OF TRENCH IS 1'-0" OR LESS, AWAY FROM CONTROL JOINT or CONSTRUCTION JOINT, SAWCUT AND REMOVE SLAB TO THE JOINT.

DO NOT CROSS CUT.

| CONCRETE FLOOR REPLACEMENT AT EXISTING SLAB | DATE: 11/10/11 |
|---|---|
| | SCALE: NONE |
| | DRAWN: ZAW |
| MASTER SPECIFICATION DETAIL | ASD—69 |

ORIGINAL ISSUE DATE 10/1/09




NOTES:

1. WHERE PREP AREA COLUMNS ARE NOT CONCEALED BY SHELVING OR EQUIPMENT, THEY MUST BE WRAPPED WITH 20 GAUGE STAINLESS STEEL.
2. ALL COLUMN COVERS TO BE 4'-0" HIGH, OR MATCH HEIGHT OF EXISTING COLUMNS.
3. CONTRACTOR TO CAULK A CONTINOUS BEAD OF CLEAR SILICONE SEALANT AROUND TOP AND BOTTOM EDGES OF STAINLESS STEEL (AFTER INSTALLATION).

| PREP AREA COLUMN COVERS | DATE: 11/15/17 |
|---|---|
| | SCALE: NONE |
| | DRAWN: ZAW |
| MASTER SPECIFICATION DETAIL | ASD—63 |

ORIGINAL ISSUE DATE 2/20/06




NOTICE:

1. ERASE ALL SHOP CORNERS.
2. ADHERE STAINLESS STEEL TO WALL WITH CLEAR SILICONE SEALANT, TOP AND BOTTOM.
3. DISCONTINUE WORK FINISH SCHEDULE FOR BASE TYPE TO BE USED.
4. 20 GA. 304 STAINLESS STEEL CORNER GUARD.

| STAINLESS STEEL CORNER GUARD | DATE: 7/29/13 |
|---|---|
| | SCALE: NONE |
| | DRAWN: TMW |
| MASTER SPECIFICATION DETAIL | ASD—55A |

ORIGINAL ISSUE DATE 7/29/13




| DOUBLE ACTING DOOR FRAME AT STUD PARTITION | DATE: 8/7/13 |
|---|---|
| | SCALE: NONE |
| | DRAWN: ZAW |
| MASTER SPECIFICATION DETAIL | ASD—56 |

ORIGINAL ISSUE DATE 6/18/09




INSTALLATION INSTRUCTIONS:

1. CORE DRILL 2 1/4" DIAMETER HOLE, 4" MIN. DEEP. DEPENDING UPON THE SIZE OF THE CORE DRILLED HOLE, POUR A SMALL AMOUNT OF EPOXY IN THE HOLE, THEN INSERT SOCKET, FILLING IN WITH EPOXY AS NEEDED. INSERT POST IN TO SOCKET AND PROP UP IN VERTICAL POSITION UNTIL EPOXY SETS. IF A LARGER DIAMETER HOLE IS MADE (MAXIMUM 2") POUR STONE MAY BE USED TO SECURE SOCKET IN PLACE

Note:
Installation Instructions From National Cart Co. For MATIONAL CART 50700004 REMOVABLE POST.

| REMOVABLE PROTECTIVE POST INSTALLATION | DATE: 5/24/16 |
|---|---|
| | SCALE: NONE |
| | DRAWN: ZAW |
| MASTER SPECIFICATION DETAIL | ASD—19 |

ORIGINAL ISSUE DATE 5/24/16




NOTE:

REFER TO SPECIFICATIONS SECTION 09 65 13.

| CARPET TRANSITION DETAILS | DATE: 7/13/16 |
|---|---|
| | SCALE: NONE |
| | DRAWN: ZAW |
| MASTER SPECIFICATION DETAIL | ASD—4E |

ORIGINAL ISSUE DATE 7/29/21




Note:

REFER TO SPECIFICATIONS FOR PRODUCTS.

| QUARRY TILE TRANSITION DETAILS | DATE: 7/29/13 |
|---|---|
| | SCALE: NONE |
| | DRAWN: ZAW |
| MASTER SPECIFICATION DETAIL | ASD—4D |

ORIGINAL ISSUE DATE 11/20/01




Note:

REFER TO SPECIFICATIONS FOR PRODUCTS.

| TILE TRANSITION DETAILS | DATE: 9/10/15 |
|---|---|
| | SCALE: NONE |
| | DRAWN: ZAW |
| MASTER SPECIFICATION DETAIL | ASD—4C |

ORIGINAL ISSUE DATE 11/20/01




NOTE:

REFER TO SPECIFICATIONS SECTION 09 65 13.

| TRANSITION DETAILS | DATE: 7/13/16 |
|---|---|
| | SCALE: NONE |
| | DRAWN: ZAW |
| MASTER SPECIFICATION DETAIL | ASD—4B |

ORIGINAL ISSUE DATE 11/20/01




Note:

1. Reference Architectural Plans for Extent of Resinous Flooring.
2. Refer to Specifications for Products.
3. Top of 1/4" thick resinous material even with rim of drain (Typical).

| RESINOUS FLOORING TRANSITIONS | DATE: 11/23/15 |
|---|---|
| | SCALE: NONE |
| | DRAWN: ZAW |
| MASTER SPECIFICATION DETAIL | ASD—4A |

ORIGINAL ISSUE DATE 7/21/01




| PROTECTIVE WOOD BUMPER RAIL | DATE: 6-6-08 |
|---|---|
| | SCALE: NONE |
| | DRAWN: JFG |
| MASTER SPECIFICATION DETAIL | ASD—2 |

## General Walltype Notes

1. DEFLECTION TRACK TO BE USED AT BOTTOM OF JOISTS. CONSISTS OF 3" LONG LEG TO PROVIDE 1-1/2" OF VERTICAL MOVEMENT. DO NOT ATTACH METAL STUD WALL OR GYPSUM BOARD TO DEFLECTION TRACK. HOLD GYPSUM BOARD SHORT OF DECK BY 1-1/2".
2. GYPSUM BOARD: TYPICAL 1/2" GYP. BOARD USED UNLESS NOTED OTHERWISE. REMODEL PROJECTS USE 5/8" GYPSUM BOARD WHERE EXISTING 5/8" GYPSUM BOARD IS IN PLACE.
3. MOISTURE RESISTANT GYPSUM BOARD: 1/2" THICK UNLESS NOTED OTHERWISE.
4. CEMENT BOARD: 1/2" UNLESS NOTED OTHERWISE.
5. METAL STUDS: STANDARD DEPTH TO BE 3 5/8" UNLESS NOTED OTHERWISE. REFER TO DETAILS FOR BRACING AND GAGE.
6. BRACING AT COOLER/FREEZER: FULL HEIGHT WALLS BUILT ALONG COOLER/FREEZER PANELS SHOULD BE BRACED AT ROOF PANEL TO UTILIZE STANDARD DEPTH METAL STUD.
7. GYPSUM BOARD AT PHARMACY GRILLE: INSTALL GYPSUM BOARD AS FAR AS POSSIBLE IN POCKET WALL FOR PHARMACY GRILLE, CONSIDER WHICH SIDE WILL BE VIEWED MOST BY CUSTOMERS WHEN INSTALLING GYPSUM BOARD.
8. FLOOR FINISH AND BASE: REFER TO INTERIOR DECOR PLANS & ROOM FINISH SCHEDULE. FOR WALL FINISHES REFER TO SPECIFICATION SECTIONS 1 AND 9.
9. FINISHED CEILINGS: EXTEND GYP. BD. 6" ABOVE CEILING, METAL STUDS DO NOT NEED TO EXTEND TO DECK (U.N.O.) IF BRACED BACK TO STRUCTURE ABOVE AT 48" O.C. MAX.
10. OSB WOOD PANEL ALLOWED FOR 5B CONSTRUCTION. USE FRT WOOD PANEL FOR 2B NONCOMBUSTIBLE CONSTRUCTION.
11. ALL PARTITION WITH RECESSED ELECTRIC PANELS AND TOILET SHALL BE 6" STUD.
12. ALL PARTIAL HEIGHT WALLS IN SUSHI AND CHEESE SHOP LOCATIONS TO BE 48" AFF. OUTLETS FOR COUNTERTOP EQUIPMENT ARE TO BE INSTALLED ALONG WALLS ARE TO BE INSTALLED ABOVE TABLE SPALSH

| # | Date | Change Description |
|---|---|---|
| | | |

KROGER N273
WORTHINGTON
60 WORTHINGTON MALL
WORTHINGTON, OH 43085
for
THE KROGER COMPANY

MOODY•NOLAN
300 Spruce Street
Suite 300
Columbus, Ohio 43215
Phone: (614) 461-4664
Fax: (614) 280-8881
www.moodynolan.com

Dwg. Coord.: NLF | Tech. Coord.: | Proj #: 19393

DETAILS and INTERIOR WALLTYPES — A5.2

95% OWNER REVIEW — 10/29/2019

PLOTTED BY: $USER$ $DATE$ $TIME$ $FILE$