



- | | | | |
|---|--|---|---|
| ① | CORNING IIR CONNECTOR HOUSING (CCH-01U) | ⑩ | 20 AMP 120 VAC ISOLATED GROUND DUPLEX RECEPTACLE (BY OTHERS) |
| ② | UPS (OWNER FURNISHED EQUIPMENT) | ⑪ | 3/4"x32"x48" AC GRADE FIRE RETARDANT PLYWOOD PAINTED V/V WHITE FIRE RETARDANT PAINT (355419-REV1) KIT WITH SCREWS AND BOLTS |
| ③ | PANDUIT MINI-CDM 48-PORT HIGH DENSITY MODULAR PATCH PANEL (CPPA48HMBWL) | ⑫ | 3" EMT CONDUIT AND REQUIRED HARDWARE TO ATTACH |
| ④ | PANDUIT MINI-CDM 48-PORT ANGLED MODULAR PATCH PANEL (CPPA48FMWBL) | ⑬ | 3" EMT BEND RADIUS CONDUIT SWEEP |
| ⑤ | NETWORK SWITCH (OWNER FURNISHED EQUIPMENT) | ⑭ | PANDUIT MINI-CDM 24 PORT ANGLED MODULAR PATCH PANEL (CPPA24FMWBL) |
| ⑥ | (NOT USED) | ⑮ | PANDUIT PAN ZONE IN-CEILING ENCLOSURE, 13.5"Hx25.5"Wx27.5"D FOR ACTIVE COMPONENTS (PZICEA) |
| ⑦ | GREAT LAKES 21.25"Wx36"Hx24.5"D WALL MOUNT SWING ARM CABINET KIT (GL36WS-KROGER) | | |
| ⑧ | GREAT LAKES 21.25"Wx48"Hx24.5"D WALL MOUNT SWING ARM CABINET KIT (GL48WS-KROGER) | | |
| ⑨ | PANDUIT IIR SINGLE SIDED CABLE ORGANIZER (CMPHF1) | | |
- NOTE: PROVIDE REQUIRED QUANTITY NOT INCLUDED WITH GREAT LAKES WALL MOUNT CABINET KIT.