




- NOTES:**
1. PIN JUMPER SET TO TEST/INIT.
  2. SP 1 & 2 DOWN.
  3. SP 1 UP FOR TEST, SP 2 DOWN, 3 WIRE DELAY.
  4. SP 1 UP FOR INSTANT GATE ALARM.
  5. SP 1 UP (SP 2-3 DOWN, 3 WIRE DELAY).
  6. ADJUSTED TO THE MODE WHICH IS A 60 SECOND DELAY FOR SHUTTING OFF AND RE-TRY.
  7. SILENCE AND FAN CONNECTIONS CONTROLLED BY FREQUENCY AND MEAT COOLERS ON HIGH VOLTAGE GATE CONTROL FANS AND ELECTRIC EXHAUST FANS ARE CONTROLLED BY GATE CONTROL.
  8. 1/4" x 1/2" x 24" MAX LENGTH ARMED CASE MOUNTED WITH WIRE.



<b>WALK-IN DOOR MONITOR</b>	DATE: 5/18/15 SCALE: NONE DRAWN: TWW/ZAW
<b>MASTER SPECIFICATION DETAIL</b>	<b>EISD-4</b>


ORIGINAL ISSUE DATE 12/18/13



- NOTES:**
1. FOR SHELVEING REFER TO FIXTURE PLAN AND SHELVEING ORDER INFORMATION.
  2. HUBBELL, INC. HBL 24GB0121V 6" 20 AMP PLUGTRAK W/OUTLETS 12" O.C. CONTROL PLUGTRAK TO OVERHEAD, OR UNDERGROUND AS REQUIRED.

<b>LAMP DECK</b>	DATE: 7/23/12 SCALE: NONE DRAWN: ZAW
<b>MASTER SPECIFICATION DETAIL</b>	<b>EISD-3</b>


ORIGINAL ISSUE DATE 7/23/12



- NOTES:**
1. DASHED LINES INDICATE HIDDEN CONDUIT IN SHELF BACK AND BASE.

<b>SHELVEING ELECTRIC FROM OVERHEAD</b>	DATE: 7/23/12 SCALE: NONE DRAWN: ZAW
<b>MASTER SPECIFICATION DETAIL</b>	<b>EISD-2</b>



ORIGINAL ISSUE DATE 7/23/12



- NOTES:**
1. The Fixture Electrical Installer shall install each motion sensor to control 2 cases maximum. When an odd number of cases are in a row one motion sensor will control only one case. See Typical - B.
  2. Motion sensors shall only be used on cases in an aisle. No motion sensors are to be placed on end cases, display doors, partition cases, etc.
  3. Motion sensors shall be mounted to one side or the other of the case joint.
  4. Owner Supplied Items: Watt Stopper motion sensor kit #P80 number K-0011767. Kit includes (1) power supply, (1) motion sensor, (1) 10' interconnect cable, (1) contractor and (1) applicator.
  5. Refer to Kroger Installation Specifications for Watt Stopper Motion Sensor for additional installation information.

<b>GLASS DOOR CASE MOTION SENSOR</b>	DATE: 3/13/12 SCALE: NONE DRAWN: ZAW
<b>MASTER SPECIFICATION DETAIL</b>	<b>EISD-1</b>



ORIGINAL ISSUE DATE 10/2/09



- NOTES:**
1. FOLLOW INSTRUCTIONS FROM CHECKSTAND MANUFACTURER SUPPLIED WITH POWER POLES FOR ASSEMBLY & METAL INSTALLATION.
  2. POWER POLE WEIGHT IS SUPPORTED BY CHECKSTAND. CUT TOP OF POWER POLE AS NECESSARY AND ATTACH TO BUILDING STRUCTURE.
  3. WHEN TOP OF POWER POLE MISSES EXISTING STRUCTURAL STEEL, PROVIDE A SECURE ATTACH A METAL SUPPORT, SUCH AS UNISTRUT CHANNEL, JOIST BRACKET, JOIST.
  4. SECURELY ATTACH POWER POLE TO EXISTING STRUCTURE OR NEW METAL SUPPORT. DO NOT DRILL THRU, RUN BOLTS THRU, OR SCREW INTO POLE. PREVENT SHARP EDGES WHICH COULD DAMAGE COMMUNICATION CABLES.
  5. 3/8" x 4" HOLE LENGTH x 4" HOLE WIDTH SQUARE HOLE, TO CONNECT TO SLOTTED METAL SUPPORT (UNISTRUT) CHANNEL, WITHOUT DRILLING, IF POWER POLE IS CENTERED ON A SLOT IN METAL SUPPORT (UNISTRUT) CHANNEL. DO NOT DRILL THRU, RUN BOLTS THRU, OR SCREW INTO POLE. PREVENT SHARP EDGES WHICH COULD DAMAGE COMMUNICATION CABLES.
  6. HOLETS REQUIRED RESULT IN POSTHOLE BRACKETS TO PARTIALLY COVER SOME ACCESS HOLES.
  7. METAL SUPPORT (UNISTRUT), SQUARE U-BOLT AND ATTACHMENT HARDWARE, MC CABLE SUPPLIED AND INSTALLED BY CONTRACTOR. ALL OTHER COMPONENTS SUPPLIED BY OWNER.
  8. LANE LIGHT IS SUPPLIED WITH 10-0' LONG CORD AND STANDARD GROUNDING PLUG. CONTRACTOR TO RUN LANE LIGHT CORD THROUGH PREDRILLED HOLES IN POWER POLE AND OUT BOTTOM OF POWER POLE TO FACTORY INSTALLED SWITCH LOCATED ON CHECKSTAND.
  9. BEFORE INSTALLING HARDWARE ON LANE LIGHT, ADJUST TO PARTIALLY CRACK HOLE. HOLE MUST BE CRACKED TO ALLOW BRACKET AT PREDESIGNATED LOCATIONS. CONTRACTOR TO RUN POWER CORD THROUGH PREDRILLED HOLES IN POWER POLE TO BE PLUGGED INTO DESIGNATED RECEPTACLES.
  10. ONE COMPARTMENT POWER POLES, LANE LIGHTS, BRACKETS AND STANDS COME FROM CHECKSTAND MANUFACTURER SUPPLIED BY OWNER INSTALLED BY CONTRACTOR.
  11. ALL HIGH VOLTAGE CONDUCTORS MUST BE WRAPPED WITH STEEL JACKETING (MC CABLE).

<b>EURO - METRO CHECKOUT POWER POLE AND LANE LIGHT INSTALLATION</b>	DATE: 6/5/15 SCALE: NONE DRAWN: ZAW
<b>MASTER SPECIFICATION DETAIL</b>	<b>ESD-62C</b>



ORIGINAL ISSUE DATE 6/5/15



- NOTES:**
1. FOLLOW INSTRUCTIONS FROM CHECKSTAND MANUFACTURER SUPPLIED WITH POWER POLES FOR ASSEMBLY & METAL INSTALLATION.
  2. POWER POLE WEIGHT IS SUPPORTED BY CHECKSTAND. CUT TOP OF POWER POLE AS NECESSARY AND ATTACH TO BUILDING STRUCTURE.
  3. WHEN TOP OF POWER POLE MISSES EXISTING STRUCTURAL STEEL, PROVIDE A SECURE ATTACH A METAL SUPPORT, SUCH AS UNISTRUT CHANNEL, JOIST BRACKET, JOIST.
  4. SECURELY ATTACH POWER POLE TO EXISTING STRUCTURE OR NEW METAL SUPPORT. DO NOT DRILL THRU, RUN BOLTS THRU, OR SCREW INTO POLE. PREVENT SHARP EDGES WHICH COULD DAMAGE COMMUNICATION CABLES.
  5. 3/8" x 4" HOLE LENGTH x 4" HOLE WIDTH SQUARE HOLE, TO CONNECT TO SLOTTED METAL SUPPORT (UNISTRUT) CHANNEL, WITHOUT DRILLING, IF POWER POLE IS CENTERED ON A SLOT IN METAL SUPPORT (UNISTRUT) CHANNEL. DO NOT DRILL THRU, RUN BOLTS THRU, OR SCREW INTO POLE. PREVENT SHARP EDGES WHICH COULD DAMAGE COMMUNICATION CABLES.
  6. HOLETS REQUIRED RESULT IN POSTHOLE BRACKETS TO PARTIALLY COVER SOME ACCESS HOLES.
  7. METAL SUPPORT (UNISTRUT), SQUARE U-BOLT AND ATTACHMENT HARDWARE, MC CABLE SUPPLIED AND INSTALLED BY CONTRACTOR. ALL OTHER COMPONENTS SUPPLIED BY OWNER.
  8. LANE LIGHT IS SUPPLIED WITH 10-0' LONG CORD AND STANDARD GROUNDING PLUG. CONTRACTOR TO RUN LANE LIGHT CORD THROUGH PREDRILLED HOLES IN POWER POLE AND OUT BOTTOM OF POWER POLE TO FACTORY INSTALLED SWITCH LOCATED ON CHECKSTAND.
  9. BEFORE INSTALLING HARDWARE ON LANE LIGHT, ADJUST TO PARTIALLY CRACK HOLE. HOLE MUST BE CRACKED TO ALLOW BRACKET AT PREDESIGNATED LOCATIONS. CONTRACTOR TO RUN POWER CORD THROUGH PREDRILLED HOLES IN POWER POLE TO BE PLUGGED INTO DESIGNATED RECEPTACLES.
  10. ONE COMPARTMENT POWER POLES, LANE LIGHTS, BRACKETS AND STANDS COME FROM CHECKSTAND MANUFACTURER SUPPLIED BY OWNER INSTALLED BY CONTRACTOR.
  11. ALL HIGH VOLTAGE CONDUCTORS MUST BE WRAPPED WITH STEEL JACKETING (MC CABLE).

<b>CAROUSEL CHECKOUT POWER POLE AND LANE LIGHT INSTALLATION</b>	DATE: 6/5/15 SCALE: NONE DRAWN: ZAW
<b>MASTER SPECIFICATION DETAIL</b>	<b>ESD-62B</b>



ORIGINAL ISSUE DATE 11/21/14



- NOTES:**
1. FOLLOW INSTRUCTIONS FROM CHECKSTAND MANUFACTURER SUPPLIED WITH POWER POLES FOR ASSEMBLY & METAL INSTALLATION. POWER POLES AS FOLLOWS:
  2. TWO PRE-CUT ACCESS HOLES ON 3" DIA OF POWER POLE FOR LIGHT AND SIGNAL. TWO PRE-CUT HOLES ON 3" DIA OF POWER POLE FOR LIGHT AND SIGNAL. TWO PRE-CUT HOLES ON 3" DIA OF POWER POLE FOR LIGHT AND SIGNAL.
  3. WHEN TOP OF POWER POLE MISSES EXISTING STRUCTURAL STEEL, PROVIDE A SECURE ATTACH A METAL SUPPORT, SUCH AS UNISTRUT CHANNEL, JOIST BRACKET, JOIST.
  4. SECURELY ATTACH POWER POLE TO EXISTING STRUCTURE OR NEW METAL SUPPORT (UNISTRUT). DO NOT DRILL THRU, RUN BOLTS THRU, OR SCREW INTO POLE. PREVENT SHARP EDGES WHICH COULD DAMAGE COMMUNICATION CABLES.
  5. 3/8" x 4" HOLE LENGTH x 4" HOLE WIDTH SQUARE HOLE, TO CONNECT TO SLOTTED METAL SUPPORT (UNISTRUT) CHANNEL, WITHOUT DRILLING, IF POWER POLE IS CENTERED ON A SLOT IN METAL SUPPORT (UNISTRUT) CHANNEL. DO NOT DRILL THRU, RUN BOLTS THRU, OR SCREW INTO POLE. PREVENT SHARP EDGES WHICH COULD DAMAGE COMMUNICATION CABLES.
  6. HOLETS REQUIRED RESULT IN POSTHOLE BRACKETS TO PARTIALLY COVER SOME ACCESS HOLES.
  7. METAL SUPPORT (UNISTRUT), SQUARE U-BOLT AND ATTACHMENT HARDWARE, MC CABLE SUPPLIED AND INSTALLED BY CONTRACTOR. ALL OTHER COMPONENTS SUPPLIED BY OWNER.
  8. LANE LIGHT IS SUPPLIED WITH 10-0' LONG CORD AND STANDARD GROUNDING PLUG. CONTRACTOR TO RUN LANE LIGHT CORD THROUGH PREDRILLED HOLES IN POWER POLE AND OUT BOTTOM OF POWER POLE TO FACTORY INSTALLED SWITCH LOCATED ON CHECKSTAND.
  9. BEFORE INSTALLING HARDWARE ON LANE LIGHT, ADJUST TO PARTIALLY CRACK HOLE. HOLE MUST BE CRACKED TO ALLOW BRACKET AT PREDESIGNATED LOCATIONS. CONTRACTOR TO RUN POWER CORD THROUGH PREDRILLED HOLES IN POWER POLE TO BE PLUGGED INTO DESIGNATED RECEPTACLES.
  10. ONE COMPARTMENT POWER POLES, LANE LIGHTS, BRACKETS AND STANDS COME FROM CHECKSTAND MANUFACTURER SUPPLIED BY OWNER INSTALLED BY CONTRACTOR.
  11. ALL HIGH VOLTAGE CONDUCTORS MUST BE WRAPPED WITH STEEL JACKETING (MC CABLE).

<b>SELF-SCAN CHECKOUT POWER POLE &amp; LANE LIGHT INSTALLATION</b>	DATE: 11/21/14 SCALE: NONE DRAWN: ZAW
<b>MASTER SPECIFICATION DETAIL</b>	<b>ESD-62A</b>



ORIGINAL ISSUE DATE 5/7/10



- NOTES:**
1. FOLLOW INSTRUCTIONS FROM CHECKSTAND MANUFACTURER SUPPLIED WITH POWER POLES FOR ASSEMBLY & METAL INSTALLATION.
  2. POWER POLE WEIGHT IS SUPPORTED BY CHECKSTAND. CUT TOP OF POWER POLE AS NECESSARY AND ATTACH TO BUILDING STRUCTURE.
  3. WHEN TOP OF POWER POLE MISSES EXISTING STRUCTURAL STEEL, PROVIDE A SECURE ATTACH A METAL SUPPORT, SUCH AS UNISTRUT CHANNEL, JOIST BRACKET, JOIST.
  4. SECURELY ATTACH POWER POLE TO EXISTING STRUCTURE OR NEW METAL SUPPORT (UNISTRUT). DO NOT DRILL THRU, RUN BOLTS THRU, OR SCREW INTO POLE. PREVENT SHARP EDGES WHICH COULD DAMAGE COMMUNICATION CABLES.
  5. 3/8" x 4" HOLE LENGTH x 4" HOLE WIDTH SQUARE HOLE, TO CONNECT TO SLOTTED METAL SUPPORT (UNISTRUT) CHANNEL, WITHOUT DRILLING, IF POWER POLE IS CENTERED ON A SLOT IN METAL SUPPORT (UNISTRUT) CHANNEL. DO NOT DRILL THRU, RUN BOLTS THRU, OR SCREW INTO POLE. PREVENT SHARP EDGES WHICH COULD DAMAGE COMMUNICATION CABLES.
  6. HOLETS REQUIRED RESULT IN POSTHOLE BRACKETS TO PARTIALLY COVER SOME ACCESS HOLES.
  7. METAL SUPPORT (UNISTRUT), SQUARE U-BOLT AND ATTACHMENT HARDWARE, MC CABLE SUPPLIED AND INSTALLED BY CONTRACTOR. ALL OTHER COMPONENTS SUPPLIED BY OWNER.
  8. LANE LIGHT IS SUPPLIED WITH 10-0' LONG CORD AND STANDARD GROUNDING PLUG. CONTRACTOR TO RUN LANE LIGHT CORD THROUGH PREDRILLED HOLES IN POWER POLE AND OUT BOTTOM OF POWER POLE TO FACTORY INSTALLED SWITCH LOCATED ON CHECKSTAND.
  9. BEFORE INSTALLING HARDWARE ON LANE LIGHT, ADJUST TO PARTIALLY CRACK HOLE. HOLE MUST BE CRACKED TO ALLOW BRACKET AT PREDESIGNATED LOCATIONS. CONTRACTOR TO RUN POWER CORD THROUGH PREDRILLED HOLES IN POWER POLE TO BE PLUGGED INTO DESIGNATED RECEPTACLES.
  10. ONE COMPARTMENT POWER POLES, LANE LIGHTS, BRACKETS AND STANDS COME FROM CHECKSTAND MANUFACTURER SUPPLIED BY OWNER INSTALLED BY CONTRACTOR.
  11. ALL HIGH VOLTAGE CONDUCTORS MUST BE WRAPPED WITH STEEL JACKETING (MC CABLE).

<b>CHECKOUT POWER POLE AND LANE LIGHT INSTALLATION</b>	DATE: 6/5/15 SCALE: NONE DRAWN: ZAW
<b>MASTER SPECIFICATION DETAIL</b>	<b>ESD-62</b>



ORIGINAL ISSUE DATE 12/18/07



- NOTES:**
1. FOLLOW INSTRUCTIONS FROM CHECKSTAND MANUFACTURER SUPPLIED WITH POWER POLES FOR ASSEMBLY & METAL INSTALLATION.
  2. POWER POLE WEIGHT IS SUPPORTED BY CHECKSTAND. CUT TOP OF POWER POLE AS NECESSARY AND ATTACH TO BUILDING STRUCTURE.
  3. WHEN TOP OF POWER POLE MISSES EXISTING STRUCTURAL STEEL, PROVIDE A SECURE ATTACH A METAL SUPPORT, SUCH AS UNISTRUT CHANNEL, JOIST BRACKET, JOIST.
  4. SECURELY ATTACH POWER POLE TO EXISTING STRUCTURE OR NEW METAL SUPPORT (UNISTRUT). DO NOT DRILL THRU, RUN BOLTS THRU, OR SCREW INTO POLE. PREVENT SHARP EDGES WHICH COULD DAMAGE COMMUNICATION CABLES.
  5. 3/8" x 4" HOLE LENGTH x 4" HOLE WIDTH SQUARE HOLE, TO CONNECT TO SLOTTED METAL SUPPORT (UNISTRUT) CHANNEL, WITHOUT DRILLING, IF POWER POLE IS CENTERED ON A SLOT IN METAL SUPPORT (UNISTRUT) CHANNEL. DO NOT DRILL THRU, RUN BOLTS THRU, OR SCREW INTO POLE. PREVENT SHARP EDGES WHICH COULD DAMAGE COMMUNICATION CABLES.
  6. HOLETS REQUIRED RESULT IN POSTHOLE BRACKETS TO PARTIALLY COVER SOME ACCESS HOLES.
  7. METAL SUPPORT (UNISTRUT), SQUARE U-BOLT AND ATTACHMENT HARDWARE, MC CABLE SUPPLIED AND INSTALLED BY CONTRACTOR. ALL OTHER COMPONENTS SUPPLIED BY OWNER.
  8. LANE LIGHT IS SUPPLIED WITH 10-0' LONG CORD AND STANDARD GROUNDING PLUG. CONTRACTOR TO RUN LANE LIGHT CORD THROUGH PREDRILLED HOLES IN POWER POLE AND OUT BOTTOM OF POWER POLE TO FACTORY INSTALLED SWITCH LOCATED ON CHECKSTAND.
  9. BEFORE INSTALLING HARDWARE ON LANE LIGHT, ADJUST TO PARTIALLY CRACK HOLE. HOLE MUST BE CRACKED TO ALLOW BRACKET AT PREDESIGNATED LOCATIONS. CONTRACTOR TO RUN POWER CORD THROUGH PREDRILLED HOLES IN POWER POLE TO BE PLUGGED INTO DESIGNATED RECEPTACLES.
  10. ONE COMPARTMENT POWER POLES, LANE LIGHTS, BRACKETS AND STANDS COME FROM CHECKSTAND MANUFACTURER SUPPLIED BY OWNER INSTALLED BY CONTRACTOR.
  11. ALL HIGH VOLTAGE CONDUCTORS MUST BE WRAPPED WITH STEEL JACKETING (MC CABLE).

<b>WINE COOLER LIGHTING</b>	DATE: 3/13/12 SCALE: NONE DRAWN: ZAW
<b>MASTER SPECIFICATION DETAIL</b>	<b>ESD-56</b>



ORIGINAL ISSUE DATE 10/2/06



- NOTES:**
1. FOLLOW INSTRUCTIONS FROM CHECKSTAND MANUFACTURER SUPPLIED WITH POWER POLES FOR ASSEMBLY & METAL INSTALLATION. POWER POLES AS FOLLOWS:
  2. TWO PRE-CUT ACCESS HOLES ON 3" DIA OF POWER POLE FOR LIGHT AND SIGNAL. TWO PRE-CUT HOLES ON 3" DIA OF POWER POLE FOR LIGHT AND SIGNAL. TWO PRE-CUT HOLES ON 3" DIA OF POWER POLE FOR LIGHT AND SIGNAL.
  3. WHEN TOP OF POWER POLE MISSES EXISTING STRUCTURAL STEEL, PROVIDE A SECURE ATTACH A METAL SUPPORT, SUCH AS UNISTRUT CHANNEL, JOIST BRACKET, JOIST.
  4. SECURELY ATTACH POWER POLE TO EXISTING STRUCTURE OR NEW METAL SUPPORT (UNISTRUT). DO NOT DRILL THRU, RUN BOLTS THRU, OR SCREW INTO POLE. PREVENT SHARP EDGES WHICH COULD DAMAGE COMMUNICATION CABLES.
  5. 3/8" x 4" HOLE LENGTH x 4" HOLE WIDTH SQUARE HOLE, TO CONNECT TO SLOTTED METAL SUPPORT (UNISTRUT) CHANNEL, WITHOUT DRILLING, IF POWER POLE IS CENTERED ON A SLOT IN METAL SUPPORT (UNISTRUT) CHANNEL. DO NOT DRILL THRU, RUN BOLTS THRU, OR SCREW INTO POLE. PREVENT SHARP EDGES WHICH COULD DAMAGE COMMUNICATION CABLES.
  6. HOLETS REQUIRED RESULT IN POSTHOLE BRACKETS TO PARTIALLY COVER SOME ACCESS HOLES.
  7. METAL SUPPORT (UNISTRUT), SQUARE U-BOLT AND ATTACHMENT HARDWARE, MC CABLE SUPPLIED AND INSTALLED BY CONTRACTOR. ALL OTHER COMPONENTS SUPPLIED BY OWNER.
  8. LANE LIGHT IS SUPPLIED WITH 10-0' LONG CORD AND STANDARD GROUNDING PLUG. CONTRACTOR TO RUN LANE LIGHT CORD THROUGH PREDRILLED HOLES IN POWER POLE AND OUT BOTTOM OF POWER POLE TO FACTORY INSTALLED SWITCH LOCATED ON CHECKSTAND.
  9. BEFORE INSTALLING HARDWARE ON LANE LIGHT, ADJUST TO PARTIALLY CRACK HOLE. HOLE MUST BE CRACKED TO ALLOW BRACKET AT PREDESIGNATED LOCATIONS. CONTRACTOR TO RUN POWER CORD THROUGH PREDRILLED HOLES IN POWER POLE TO BE PLUGGED INTO DESIGNATED RECEPTACLES.
  10. ONE COMPARTMENT POWER POLES, LANE LIGHTS, BRACKETS AND STANDS COME FROM CHECKSTAND MANUFACTURER SUPPLIED BY OWNER INSTALLED BY CONTRACTOR.
  11. ALL HIGH VOLTAGE CONDUCTORS MUST BE WRAPPED WITH STEEL JACKETING (MC CABLE).

<b>COLUMN MOUNTED PRICE CHECKER SECTIONS</b>	DATE: 1/30/09 SCALE: NONE DRAWN: JFQ
<b>MASTER SPECIFICATION DETAIL</b>	<b>ESD-55</b>



ORIGINAL ISSUE DATE 1/30/09



- NOTES:**
1. FOLLOW INSTRUCTIONS FROM CHECKSTAND MANUFACTURER SUPPLIED WITH POWER POLES FOR ASSEMBLY & METAL INSTALLATION.
  2. POWER POLE WEIGHT IS SUPPORTED BY CHECKSTAND. CUT TOP OF POWER POLE AS NECESSARY AND ATTACH TO BUILDING STRUCTURE.
  3. WHEN TOP OF POWER POLE MISSES EXISTING STRUCTURAL STEEL, PROVIDE A SECURE ATTACH A METAL SUPPORT, SUCH AS UNISTRUT CHANNEL, JOIST BRACKET, JOIST.
  4. SECURELY ATTACH POWER POLE TO EXISTING STRUCTURE OR NEW METAL SUPPORT (UNISTRUT). DO NOT DRILL THRU, RUN BOLTS THRU, OR SCREW INTO POLE. PREVENT SHARP EDGES WHICH COULD DAMAGE COMMUNICATION CABLES.
  5. 3/8" x 4" HOLE LENGTH x 4" HOLE WIDTH SQUARE HOLE, TO CONNECT TO SLOTTED METAL SUPPORT (UNISTRUT) CHANNEL, WITHOUT DRILLING, IF POWER POLE IS CENTERED ON A SLOT IN METAL SUPPORT (UNISTRUT) CHANNEL. DO NOT DRILL THRU, RUN BOLTS THRU, OR SCREW INTO POLE. PREVENT SHARP EDGES WHICH COULD DAMAGE COMMUNICATION CABLES.
  6. HOLETS REQUIRED RESULT IN POSTHOLE BRACKETS TO PARTIALLY COVER SOME ACCESS HOLES.
  7. METAL SUPPORT (UNISTRUT), SQUARE U-BOLT AND ATTACHMENT HARDWARE, MC CABLE SUPPLIED AND INSTALLED BY CONTRACTOR. ALL OTHER COMPONENTS SUPPLIED BY OWNER.
  8. LANE LIGHT IS SUPPLIED WITH 10-0' LONG CORD AND STANDARD GROUNDING PLUG. CONTRACTOR TO RUN LANE LIGHT CORD THROUGH PREDRILLED HOLES IN POWER POLE AND OUT BOTTOM OF POWER POLE TO FACTORY INSTALLED SWITCH LOCATED ON CHECKSTAND.
  9. BEFORE INSTALLING HARDWARE ON LANE LIGHT, ADJUST TO PARTIALLY CRACK HOLE. HOLE MUST BE CRACKED TO ALLOW BRACKET AT PREDESIGNATED LOCATIONS. CONTRACTOR TO RUN POWER CORD THROUGH PREDRILLED HOLES IN POWER POLE TO BE PLUGGED INTO DESIGNATED RECEPTACLES.
  10. ONE COMPARTMENT POWER POLES, LANE LIGHTS, BRACKETS AND STANDS COME FROM CHECKSTAND MANUFACTURER SUPPLIED BY OWNER INSTALLED BY CONTRACTOR.
  11. ALL HIGH VOLTAGE CONDUCTORS MUST BE WRAPPED WITH STEEL JACKETING (MC CABLE).

<b>COLUMN MOUNTED CONVENIENCE OUTLET SECTIONS</b>	DATE: 11/10/11 SCALE: NONE DRAWN: ZAW
<b>MASTER SPECIFICATION DETAIL</b>	<b>ESD-54</b>



ORIGINAL ISSUE DATE 1/30/09



- NOTES:**
1. ALL ELECTRICAL APPARATUS SHALL BE PROVIDED BY KROGER. ALL EQUIPMENT TO BE INSTALLED BY THE ELECTRICAL CONTRACTOR.
  2. LANE LIGHT AND 120 VOLT WIRING IS FURNISHED AND INSTALLED BY THE ELECTRICAL CONTRACTOR.
  3. ALL LOW VOLTAGE HANG CONTROLS AND TELEPHONE WIRING IS BY OWNER.
  4. EACH LIGHTING CONTROL FURNISHED BY KROGER SHALL CONTAIN A TWO-WIRE CONTROL MODULE FOR FUTURE TO ROOM METAL DECKING SHALL NOT BE PERMITTED.

<b>CONTROL PANEL DIAGRAM</b>	DATE: 1/11/11 SCALE: NONE DRAWN: JFQ
<b>MASTER SPECIFICATION DETAIL</b>	<b>ESD-53</b>



ORIGINAL ISSUE DATE 2/20/06



- NOTES:**
1. DIGITAL PEDESTAL TO BE CENTERED ON CORE DRILLED HOLES, AND SHOULD NOT INTERFERE WITH THE EMERGENCY OPERATION OF DOORS. SPACE BETWEEN PEDESTALS SHALL NOT EXCEED 6'-0".
  2. IF THE INTERCONNECT CABLE FROM PRIMARY TO SECONDARY PEDESTAL IS ROUTED OVER TOP OF DOORS, THE MAXIMUM CABLE DISTANCE BETWEEN THE PEDESTALS IS 30'-0".
  3. VOICE MESSAGE UNIT & EVENT RESPONSE PANEL LOCATIONS INDICATED ARE RECOMMENDATIONS ONLY. ADJUST LOCATIONS AS SITE CONDITIONS DICTATE. ERP IS OPTIONAL, AND IS FIELD DETERMINED BY LOSS PREVENTION.
  4. ELECTRICAL CONTRACTOR SHALL CORE DRILL 3/4" HOLES AND PROVIDE AFTER SET INSERTS & PULL STRING IN CONDUIT AND IN DUCT FROM PRIMARY PEDESTAL TO SECONDARY PEDESTAL.
  5. 3/4" CONDUIT FOR MAXIMUM 2 PEDESTALS) FOR LOW VOLTAGE WIRING FROM EVENT RESPONSE PANEL. CABLE/CONDUIT LENGTH NOT TO EXCEED 10 FEET TO THE FARTHEST PEDESTAL. ROUTE CONDUIT INSIDE WALL THEN UNDER FLOOR AND TERMINATE INTO END OF UNDERFLOOR DUCT.
  6. FOR NEW CONCRETE FLOOR INSTALL NO. 2 UNDERFLOOR DUCT, WITH 3/4" CONDUIT ADAPTER ON END WHERE CONDUIT ENTER DUCT AND A DUCT END PLUG ON OPPOSITE END. TOP OF UNDERFLOOR DUCT TO BE LOCATED BELOW BOTTOM OF FLOOR SLAB. FOR EXISTING CONCRETE FLOORS SAW CUT FLOOR 1/2" WIDE x 1/2" DEEP JOINT FOR CABLE IN LEU OF UNDERFLOOR DUCT. FILL JOINT WITH POLYURETHANE JOINT SEALANT TO MATCH ADJACENT JOINTS.
  7. AC POWER - 3 WIRE, 24 HOUR CIRCUIT, HARD WIRED. CONDUIT TO STUB UP AT DESIGNATED LOCATIONS OF PRIMARY DIGITAL PEDESTAL AND CUT 1" HIGH MAXIMUM ABOVE FINISHED FLOOR.

<b>SURVEILLANCE SYSTEM - RESTROOMS &amp; GRAB &amp; GO</b>	DATE: 6/5/15 SCALE: NONE DRAWN: ZAW
<b>MASTER SPECIFICATION DETAIL</b>	<b>ESD-52A</b>

ORIGINAL ISSUE DATE 6/5/15



- NOTES:**
1. DIGITAL PEDESTAL TO BE CENTERED ON CORE DRILLED HOLES, AND SHOULD NOT INTERFERE WITH THE EMERGENCY OPERATION OF DOORS. SPACE BETWEEN PEDESTALS SHALL NOT EXCEED 6'-0".
  2. CABLE LENGTH FROM CONTROLLER AS FOLLOWS: 45'-0" MAXIMUM CABLE. CONTROLLER TO EVENT RESPONSE PANEL - 30'-0" MAXIMUM CABLE.
  3. CONTROLLER LOCATION INDICATED IS RECOMMENDED FOR VESTIBULE WITH SLO PARTITIONS. FOR VESTIBULES WITHOUT SLO PARTITIONS (E.G. GLASS) LOCATE CONTROLLER AS BEST MEET FIELD CONDITIONS, BUT MAINTAINING THE MAXIMUM CABLE LENGTH INDICATED ABOVE.
  4. CONTROLLER, VOICE MESSAGE UNIT & EVENT RESPONSE PANEL LOCATIONS INDICATED ARE RECOMMENDATIONS ONLY. ADJUST LOCATIONS AS SITE CONDITIONS DICTATE. ERP IS OPTIONAL, AND IS FIELD DETERMINED BY LOSS PREVENTION.
  5. ELECTRICAL CONTRACTOR SHALL CORE DRILL 3/4" HOLES AND PROVIDE AFTER SET INSERTS & PULL STRING IN CONDUIT AND IN DUCT FROM PRIMARY PEDESTAL TO SECONDARY PEDESTAL. ONE CONTROLLER MAY CONTROL TWO PEDESTALS. TWO PEDESTALS SHALL BE CONTROLLED BY ONE CONTROLLER. TWO PEDESTALS SHALL BE CONTROLLED BY ONE CONTROLLER. TWO PEDESTALS SHALL BE CONTROLLED BY ONE CONTROLLER.
  6. FOR NEW CONCRETE FLOOR INSTALL NO. 2 UNDERFLOOR DUCT, WITH 3/4" CONDUIT ADAPTER ON END WHERE CONDUIT ENTER DUCT AND A DUCT END PLUG ON OPPOSITE END. TOP OF UNDERFLOOR DUCT TO BE LOCATED BELOW BOTTOM OF FLOOR SLAB. FOR EXISTING CONCRETE FLOORS SAW CUT FLOOR 1/2" WIDE x 1/2" DEEP JOINT FOR CABLE IN LEU OF UNDERFLOOR DUCT. FILL JOINT WITH POLYURETHANE JOINT SEALANT TO MATCH ADJACENT JOINTS.

<b>SURVEILLANCE SYSTEM - ENTRANCE</b>	DATE: 6/5/15 SCALE: NONE DRAWN: ZAW
<b>MASTER SPECIFICATION DETAIL</b>	<b>ESD-52</b>

ORIGINAL ISSUE DATE 2/20/06

