(NEW) LP-HA

480Y/277V 100A BUS 3PH 4W MLO MIN 22KAIC SURFACE

POLE	TYPE	TRIP	WIRE	CND	DESCRIPTION	LTG	RECP	KIT	SPC HEAT	SPC COOL	HTRS	ELEV	MISC
1	–	20	3#10+1#10GRD	3/4"	TYPE B2 (INBOARD 4L)	2304	–	–	–	–	–	–	–
3					TYPE B2 (OUTBOARD 2L)	1152	–	–	–	–	–	–	–
5	–	20	3#10+1#10GRD	3/4"	TYPE B2 (INBOARD 4L)	1024	–	–	–	–	–	–	–
7					TYPE B2 (OUTBOARD 2L)	512	–	–	–	–	–	–	–
9	–	20	3#10+1#10GRD	3/4"	TYPE B2 (INBOARD 4L)	2432	–	–	–	–	–	–	–
11					TYPE B2 (OUTBOARD 2L)	1216	–	–	–	–	–	–	–
13	–	20	3#10+1#10GRD	3/4"	TYPE B2 (INBOARD 4L)	2432	–	–	–	–	–	–	–
15					TYPE B2 (OUTBOARD 2L)	1216	–	–	–	–	–	–	–
17	–	20	3#10+1#10GRD	3/4"	TYPE B2 (INBOARD 4L)	2560	–	–	–	–	–	–	–
19					TYPE B2 (OUTBOARD 2L)	1280	–	–	–	–	–	–	–
21	–	20	3#10+1#10GRD	3/4"	TYPE B4 (INBOARD 2L)	768	–	–	–	–	–	–	–
23					TYPE B4 (OUTBOARD 2L)	768	–	–	–	–	–	–	–
25	–	20	2#10+1#10GRD	3/4"	TYPE F PERIMETER LIGHTS	603	–	–	–	–	–	–	–
27	–	–	–	–	–	–	–	–	–	–	–	–	–
29	–	–	–	–	–	–	–	–	–	–	–	–	–
31	–	–	–	–	–	–	–	–	–	–	–	–	–
33	–	–	–	–	–	–	–	–	–	–	–	–	–
35	–	–	–	–	–	–	–	–	–	–	–	–	–
37	–	–	–	–	–	–	–	–	–	–	–	–	–
39	–	–	–	–	–	–	–	–	–	–	–	–	–
41	–	–	–	–	–	–	–	–	–	–	–	–	–
43	–	–	–	–	–	–	–	–	–	–	–	–	–
45	–	–	–	–	–	–	–	–	–	–	–	–	–
47	–	–	–	–	–	–	–	–	–	–	–	–	–
49	–	–	–	–	–	–	–	–	–	–	–	–	–
51	–	–	–	–	–	–	–	–	–	–	–	–	–
53	–	–	–	–	–	–	–	–	–	–	–	–	–
2	–	20	2#10+1#10GRD	3/4"	SUSHI, WINE CELLAR LIGHTS	272	–	–	–	–	–	–	–
4	–	20	2#10+1#10GRD	3/4"	ACCTG, CUST SERVE, OFFICE, PHARM LTS	936	–	–	–	–	–	–	–
6	–	20	2#10+1#10GRD	3/4"	BACK OF HOUSE LIGHTS	980	–	–	–	–	–	–	–
8	–	20	2#10+1#10GRD	3/4"	BAKERY, PRODUCE, MEAT, SEAFOOD LIGHTS	2403	–	–	–	–	–	–	–
10	–	20	2#10+1#10GRD	3/4"	BREAK ROOM, MEZZANINE, RESTROOM LTS	1074	–	–	–	–	–	–	–
12	–	20	2#10+1#10GRD	3/4"	DELI, JUICE BAR, MURRAY'S LIGHTS	2568	–	–	–	–	–	–	–
14	–	–	–	–	–	–	–	–	–	–	–	–	–
16	–	–	–	–	–	–	–	–	–	–	–	–	–
18	–	–	–	–	–	–	–	–	–	–	–	–	–
20	–	–	–	–	–	–	–	–	–	–	–	–	–
22	–	–	–	–	–	–	–	–	–	–	–	–	–
24	–	–	–	–	–	–	–	–	–	–	–	–	–
26	–	–	–	–	–	–	–	–	–	–	–	–	–
28	–	–	–	–	–	–	–	–	–	–	–	–	–
30	–	–	–	–	–	–	–	–	–	–	–	–	–
32	–	–	–	–	–	–	–	–	–	–	–	–	–
34	–	–	–	–	–	–	–	–	–	–	–	–	–
36	–	–	–	–	–	–	–	–	–	–	–	–	–
38	–	–	–	–	–	–	–	–	–	–	–	–	–
40	–	–	–	–	–	–	–	–	–	–	–	–	–
42	–	–	–	–	–	–	–	–	–	–	–	–	–
44	–	–	–	–	–	–	–	–	–	–	–	–	–
46	–	–	–	–	–	–	–	–	–	–	–	–	–
48	–	–	–	–	–	–	–	–	–	–	–	–	–
50	–	–	–	–	–	–	–	–	–	–	–	–	–
52	–	–	–	–	–	–	–	–	–	–	–	–	–
54	–	–	–	–	–	–	–	–	–	–	–	–	–

CONNECTED LOAD (VA)	26500	SUBTOTAL	26500	–	–	–	–	–	–	–	–	–	–
DEMAND LOAD (VA)	33125	DEMAND	1.25	–	–	–	–	–	–	–	–	–	–
DEMAND LOAD (A)	40	TOTAL	33125	–	–	–	–	–	–	–	–	–	–

(NEW) LP-HC

480Y/277V 100A BUS 3PH 4W MLO MIN 22KAIC SURFACE

POLE	TYPE	TRIP	WIRE	CND	DESCRIPTION	LTG	RECP	KIT	SPC HEAT	SPC COOL	HTRS	ELEV	MISC
1	–	–	–	–	–	–	–	–	–	–	–	–	–
3	–	–	–	–	–	–	–	–	–	–	–	–	–
5	–	–	–	–	–	–	–	–	–	–	–	–	–
7	–	–	–	–	–	–	–	–	–	–	–	–	–
9	–	–	–	–	–	–	–	–	–	–	–	–	–
11	–	–	–	–	–	–	–	–	–	–	–	–	–
13	–	–	–	–	–	–	–	–	–	–	–	–	–
15	–	–	–	–	–	–	–	–	–	–	–	–	–
17	–	–	–	–	–	–	–	–	–	–	–	–	–
19	–	–	–	–	–	–	–	–	–	–	–	–	–
21	–	–	–	–	–	–	–	–	–	–	–	–	–
23	–	–	–	–	–	–	–	–	–	–	–	–	–
25	–	–	–	–	–	–	–	–	–	–	–	–	–
27	–	–	–	–	–	–	–	–	–	–	–	–	–
29	–	–	–	–	–	–	–	–	–	–	–	–	–
31	–	–	–	–	–	–	–	–	–	–	–	–	–
33	–	–	–	–	–	–	–	–	–	–	–	–	–
35	–	–	–	–	–	–	–	–	–	–	–	–	–
37	–	–	–	–	–	–	–	–	–	–	–	–	–
39	–	–	–	–	–	–	–	–	–	–	–	–	–
41	–	–	–	–	–	–	–	–	–	–	–	–	–
43	–	–	–	–	–	–	–	–	–	–	–	–	–
45	–	–	–	–	–	–	–	–	–	–	–	–	–
47	–	–	–	–	–	–	–	–	–	–	–	–	–
49	–	–	–	–	–	–	–	–	–	–	–	–	–
51	–	–	–	–	–	–	–	–	–	–	–	–	–
53	–	–	–	–	–	–	–	–	–	–	–	–	–
2	–	–	–	–	–	–	–	–	–	–	–	–	–
4	–	–	–	–	–	–	–	–	–	–	–	–	–
6	–	–	–	–	–	–	–	–	–	–	–	–	–
8	–	–	–	–	–	–	–	–	–	–	–	–	–
10	–	–	–	–	–	–	–	–	–	–	–	–	–
12	–	–	–	–	–	–	–	–	–	–	–	–	–
14	–	–	–	–	–	–	–	–	–	–	–	–	–
16	–	–	–	–	–	–	–	–	–	–	–	–	–
18	–	–	–	–	–	–	–	–	–	–	–	–	–
20	–	–	–	–	–	–	–	–	–	–	–	–	–
22	–	–	–	–	–	–	–	–	–	–	–	–	–
24	–	–	–	–	–	–	–	–	–	–	–	–	–
26	–	–	–	–	–	–	–	–	–	–	–	–	–
28	–	–	–	–	–	–	–	–	–	–	–	–	–
30	–	–	–	–	–	–	–	–	–	–	–	–	–
32	–	–	–	–	–	–	–	–	–	–	–	–	–
34	–	–	–	–	–	–	–	–	–	–	–	–	–
36	–	–	–	–	–	–	–	–	–	–	–	–	–
38	–	–	–	–	–	–	–	–	–	–	–	–	–
40	–	–	–	–	–	–	–	–	–	–	–	–	–
42	–	–	–	–	–	–	–	–	–	–	–	–	–
44	–	–	–	–	–	–	–	–	–	–	–	–	–
46	–	–	–	–	–	–	–	–	–	–	–	–	–
48	–	–	–	–	–	–	–	–	–	–	–	–	–
50	–	–	–	–	–	–	–	–	–	–	–	–	–
52	–	–	–	–	–	–	–	–	–	–	–	–	–
54	–	–	–	–	–	–	–	–	–	–	–	–	–

CONNECTED LOAD (VA)	–	SUBTOTAL	–	–	–	–	–	–	–	–	–	–	–
DEMAND LOAD (VA)	–	DEMAND	–	–	–	–	–	–	–	–	–	–	–
DEMAND LOAD (A)	–	TOTAL	–	–	–	–	–	–	–	–	–	–	–

(NEW) LP-LB

208Y/120V 200A BUS 3PH 4W MLO MIN 22KAIC SURFACE

POLE	TYPE	TRIP	WIRE	CND	DESCRIPTION	LTG	RECP	KIT	SPC HEAT	SPC COOL	HTRS	ELEV	MISC
1	–	20	2#10+1#10GRD	3/4"	SYS D15	–	–	924	–	–	–	–	–
3	–	20	2#10+1#10GRD	3/4"	SYS D16	–	–	171	–	–	–	–	–
5	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
7	–	20	2#10+1#10GRD	3/4"	SYS D18	–	–	204	–	–	–	–	–
9	–	20	2#10+1#10GRD	3/4"	SYS D19	–	–	635	–	–	–	–	–
11	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
13	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
15	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
17	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
19	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
21	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
23	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
25	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
27	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
29	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
31	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
33	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
35	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
37	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
39	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
41	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
43	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
45	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
47	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
49	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
51	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
53	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
2	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
4	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
6	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
8	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
10	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
12	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
14	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
16	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
18	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
20	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
22	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
24	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
26	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
28	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
30	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
32	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
34	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
36	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
38	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
40	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
42	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
44	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
46	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
48	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
50	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
52	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
54	–	20	–	–	SPARE	–	–	–	–	–	–	–	–

CONNECTED LOAD (VA)	1934	SUBTOTAL	–	–	1934	–	–	–	–	–	–	–	–
DEMAND LOAD (VA)	1257	DEMAND	–	–	0.65	–	–	–	–	–	–	–	–
DEMAND LOAD (A)	3	TOTAL	–	–	1257	–	–	–	–	–	–	–	–

(NEW) LP-HB

480Y/277V 100A BUS 3PH 4W MLO MIN 22KAIC SURFACE

POLE	TYPE	TRIP	WIRE	CND	DESCRIPTION	LTG	RECP	KIT	SPC HEAT	SPC COOL	HTRS	ELEV	MISC
1	–	–	–	–	–	–	–	–	–	–	–	–	–
3	–	–	–	–	–	–	–	–	–	–	–	–	–
5	–	–	–	–	–	–	–	–	–	–	–	–	–
7	–	–	–	–	–	–	–	–	–	–	–	–	–
9	–	–	–	–	–	–	–	–	–	–	–	–	–
11	–	–	–	–	–	–	–	–	–	–	–	–	–
13	–	–	–	–	–	–	–	–	–	–	–	–	–
15	–	–	–	–	–	–	–	–	–	–	–	–	–
17	–	–	–	–	–	–	–	–	–	–	–	–	–
19	–	–	–	–	–	–	–	–	–	–	–	–	–
21	–	–	–	–	–	–	–	–	–	–	–	–	–
23	–	–	–	–	–	–	–	–	–	–	–	–	–
25	–	–	–	–	–	–	–	–	–	–	–	–	–
27	–	–	–	–	–	–	–	–	–	–	–	–	–
29	–	–	–	–	–	–	–	–	–	–	–	–	–
31	–	–	–	–	–	–	–	–	–	–	–	–	–
33	–	–	–	–	–	–	–	–	–	–	–	–	–
35	–	–	–	–	–	–	–	–	–	–	–	–	–
37	–	–	–	–	–	–	–	–	–	–	–	–	–
39	–	–	–	–	–	–	–	–	–	–	–	–	–
41	–	–	–	–	–	–	–	–	–	–	–	–	–
43	–	–	–	–	–	–	–	–	–	–	–	–	–
45	–	–	–	–	–	–	–	–	–	–	–	–	–
47	–	–	–	–	–	–	–	–	–	–	–	–	–
49	–	–	–	–	–	–	–	–	–	–	–	–	–
51	–	20	2#10+1#10GRD	3/4"	HDR	–	–	–	–	–	–	–	1524
53	–	20	2#10+1#10GRD	3/4"	HDR	–	–	–	–	–	–	–	1524
2	–	–	–	–	–	–	–	–	–	–	–	–	–
4	–	–	–	–	–	–	–	–	–	–	–	–	–
6	–	–	–	–	–	–	–	–	–	–	–	–	–
8	–	–	–	–	–	–	–	–	–	–	–	–	–
10	–	–	–	–	–	–	–	–	–	–	–	–	–
12	–	–	–	–	–	–	–	–	–	–	–	–	–
14	–	–	–	–	–	–	–	–	–	–	–	–	–
16	–	–	–	–	–	–	–	–	–	–	–	–	–
18	–	–	–	–	–	–	–	–	–	–	–	–	–
20	–	–	–	–	–	–	–	–	–	–	–	–	–
22	–	–	–	–	–	–	–	–	–	–	–	–	–
24	–	–	–	–	–	–	–	–	–	–	–	–	–
26	–	–	–	–	–	–	–	–	–	–	–	–	–
28	–	–	–	–	–	–	–	–	–	–	–	–	–
30	–	–	–	–	–	–	–	–	–	–	–	–	–
32	–	–	–	–	–	–	–	–	–	–	–	–	–
34	–	–	–	–	–	–	–	–	–	–	–	–	–
36	–	–	–	–	–	–	–	–	–	–	–	–	–
38	–	–	–	–	–	–	–	–	–	–	–	–	–
40	–	–	–	–	–	–	–	–	–	–	–	–	–
42	–	–	–	–	–	–	–	–	–	–	–	–	–
44	–	–	–	–	–	–	–	–	–	–	–	–	–
46	–	–	–	–	–	–	–	–	–	–	–	–	–
48	–	–	–	–	–	–	–	–	–	–	–	–	–
50	–	–	–	–	–	–	–	–	–	–	–	–	–
52	–	–	–	–	–	–	–	–	–	–	–	–	–
54	–	–	–	–	–	–	–	–	–	–	–	–	–

CONNECTED LOAD (VA)	3048	SUBTOTAL	–	–	–	–	–	–	–	–	–	–	3048
DEMAND LOAD (VA)	3048	DEMAND	–	–	–	–	–	–	–	–	–	–	1.00
DEMAND LOAD (A)	8	TOTAL	–	–	–	–	–	–	–	–	–	–	3048

(NEW) LP-LA

208Y/120V 200A BUS 3PH 4W MLO MIN 22KAIC SURFACE

POLE	TYPE	TRIP	WIRE	CND	DESCRIPTION	LTG	RECP	KIT	SPC HEAT	SPC COOL	HTRS	ELEV	MISC
1	–	20	2#10+1#10GRD	3/4"	SYS A02A, A02B	–	–	1066	–	–	–	–	–
3	–	20	2#10+1#10GRD	3/4"	SYS A02C	–	–	889	–	–	–	–	–
5	–	20	2#10+1#10GRD	3/4"	SYS A03A	–	–	889	–	–	–	–	–
7	–	20	2#10+1#10GRD	3/4"	SYS A03B	–	–	889	–	–	–	–	–
9	–	20	2#10+1#10GRD	3/4"	SYS A05A	–	–	889	–	–	–	–	–
11	–	20	2#10+1#10GRD	3/4"	SYS A05B	–	–	889	–	–	–	–	–
13	–	20	2#10+1#10GRD	3/4"	SYS A05C	–	–	889	–	–	–	–	–
15	–	20	2#10+1#10GRD	3/4"	SYS A06	–	–	355	–	–	–	–	–
17	–	20	2#10+1#10GRD	3/4"	SYS A07A	–	–	889	–	–	–	–	–
19	–	20	2#10+1#10GRD	3/4"	SYS A07B	–	–	889	–	–	–	–	–
21	–	20	2#10+1#10GRD	3/4"	SYS A07C, A07D	–	–	1066	–	–	–	–	–
23	–	20	2#10+1#10GRD	3/4"	SYS A08	–	–	355	–	–	–	–	–
25	–	20	2#10+1#10GRD	3/4"	SYS A11	–	–	710	–	–	–	–	–
27	–	20	2#10+1#10GRD	3/4"	SYS A12	–	–	889	–	–	–	–	–
29	–	20	2#10+1#10GRD	3/4"	SYS B01	–	–	216	–	–	–	–	–
31	–	20	2#10+1#10GRD	3/4"	SYS B02	–	–	824	–	–	–	–	–
33	–	20	2#10+1#10GRD	3/4"	SYS B03	–	–	306	–	–	–	–	–
35	–	20	2#10+1#10GRD	3/4"	SYS B04	–	–	659	–	–	–	–	–
37	–	20	2#10+1#10GRD	3/4"	SYS B05	–	–	390	–	–	–	–	–
39	–	20	2#10+1#10GRD	3/4"	SYS B06	–	–	520	–	–	–	–	–
41	–	20	2#10+1#10GRD	3/4"	SYS B07	–	–	912	–	–	–	–	–
43	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
45	–	20	2#10+1#10GRD	3/4"	SYS B09	–	–	348	–	–	–	–	–
47	–	20	2#10+1#10GRD	3/4"	SYS B07 AS HTRS	–	–	960	–	–	–	–	–
49	–	20	2#10+1#10GRD	3/4"	SYS B07 LIGHTS	–	–	1040	–	–	–	–	–
51	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
53	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
2	–	20	2#10+1#10GRD	3/4"	SYS C01	–	–	202	–	–	–	–	–
4	–	20	2#10+1#10GRD	3/4"	SYS C02	–	–	108	–	–	–	–	–
6	–	20	2#10+1#10GRD	3/4"	SYS C03	–	–	224	–	–	–	–	–
8	–	20	2#10+1#10GRD	3/4"	SYS C04	–	–	264	–	–	–	–	–
10	–	20	2#10+1#10GRD	3/4"	SYS C05	–	–	438	–	–	–	–	–
12	–	20	2#10+1#10GRD	3/4"	SYS C06	–	–	174	–	–	–	–	–
14	–	20	2#10+1#10GRD	3/4"	SYS C07	–	–	528	–	–	–	–	–
16	–	20	3#10+1#10GRD	3/4"	SYS C08	–	–	1789	–	–	–	–	–
18													
20	–	20	2#10+1#10GRD	3/4"	SYS C09	–	–	78	–	–	–	–	–
22	–	20	2#10+1#10GRD	3/4"	SYS C10	–	–	174	–	–	–	–	–
24	–	20	2#10+1#10GRD	3/4"	SYS C11	–	–	44	–	–	–	–	–
26	–	20	2#10+1#10GRD	3/4"	SYS C12	–	–	396	–	–	–	–	–
28	–	20	2#10+1#10GRD	3/4"	SYS D01	–	–	314	–	–	–	–	–
30	–	20	2#10+1#10GRD	3/4"	SYS D02	–	–	650	–	–	–	–	–
32	–	20	2#10+1#10GRD	3/4"	SYS D05	–	–	576	–	–	–	–	–
34	–	20	2#10+1#10GRD	3/4"	SYS D06	–	–	216	–	–	–	–	–
36	–	20	2#10+1#10GRD	3/4"	SYS D07	–	–	1200	–	–	–	–	–
38	–	20	2#10+1#10GRD	3/4"	SYS D08	–	–	456	–	–	–	–	–
40	–	20	2#10+1#10GRD	3/4"	SYS D09	–	–	216	–	–	–	–	–
42	–	20	2#10+1#10GRD	3/4"	SYS D10	–	–	348	–	–	–	–	–
44	–	20	2#10+1#10GRD	3/4"	SYS D11	–	–	1122	–	–	–	–	–
46	–	20	2#10+1#10GRD	3/4"	SYS D12	–	–	338	–	–	–	–	–
48	–	20	2#10+1#10GRD	3/4"	SYS D13	–	–	95	–	–	–	–	–
50	–	20	2#10+1#10GRD	3/4"	SYS D14	–	–	1087	–	–	–	–	–
52	–	20	2#10+1#10GRD	3/4"	SYS D14	–	–	1087	–	–	–	–	–
54	–	20	2#10+1#10GRD	3/4"	SYS D14	–	–	1622	–	–	–	–	–

CONNECTED LOAD (VA)	31474	SUBTOTAL	–	–	31474	–	–	–	–	–	–	–	–
DEMAND LOAD (VA)	20458	DEMAND	–	–	0.65	–	–	–	–	–	–	–	–
DEMAND LOAD (A)	57	TOTAL	–	–	20458	–	–	–	–	–	–	–	–

(NEW) LP-LC

208Y/120V 200A BUS 3PH 4W MLO MIN 22KAIC SURFACE

POLE	TYPE	TRIP	WIRE	CND	DESCRIPTION	LTG	RECP	KIT	SPC HEAT	SPC COOL	HTRS	ELEV	MISC
1	–	20	2#10+1#10GRD	3/4"	FLORAL TRACK LIGHTS	1200	–	–	–	–	–	–	–
3	–	20	2#10+1#10GRD	3/4"	PRODUCE TRACK LIGHTS	1200	–	–	–	–	–	–	–
5	–	20	2#10+1#10GRD	3/4"	PRODUCE TRACK LIGHTS	1200	–	–	–	–	–	–	–
7	–	20	2#10+1#10GRD	3/4"	PRODUCE TRACK LIGHTS	1800	–	–	–	–	–	–	–
9	–	20	2#10+1#10GRD	3/4"	PRODUCE TRACK LIGHTS	1800	–	–	–	–	–	–	–
11	–	20	2#10+1#10GRD	3/4"	WINE TRACK LIGHTS	420	–	–	–	–	–	–	–
13	–	20	2#10+1#10GRD	3/4"	BAKERY TRACK LIGHTS	1500	–	–	–	–	–	–	–
15	–	20	2#10+1#10GRD	3/4"	DECOR TRACK LIGHTS	1500	–	–	–	–	–	–	–
17	–	20	2#10+1#10GRD	3/4"	DECOR TRACK LIGHTS	1500	–	–	–	–	–	–	–
19	–	20	2#10+1#10GRD	3/4"	DECOR TRACK LIGHTS	1500	–	–	–	–	–	–	–
21	–	20	2#10+1#10GRD	3/4"	DECOR TRACK LIGHTS	900	–	–	–	–	–	–	–
23	–	20	2#10+1#10GRD	3/4"	BEVERAGE TRACK LIGHTS	1200	–	–	–	–	–	–	–
25	–	20	2#10+1#10GRD	3/4"	BEVERAGE TRACK LIGHTS	1200	–	–	–	–	–	–	–
27	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
29	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
31	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
33	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
35	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
37	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
39	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
41	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
43	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
45	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
47	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
49	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
51	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
53	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
2	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
4	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
6	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
8	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
10	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
12	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
14	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
16	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
18	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
20	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
22	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
24	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
26	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
28	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
30	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
32	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
34	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
36	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
38	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
40	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
42	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
44	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
46	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
48	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
50	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
52	–	20	–	–	SPARE	–	–	–	–	–	–	–	–
54	–	20	–	–	SPARE	–	–	–	–	–	–	–	–

CONNECTED LOAD (VA)	16920	SUBTOTAL	16920	–	–	–	–	–	–	–	–	–	–
DEMAND LOAD (VA)	21150	DEMAND	1.25	–	–	–	–	–	–	–	–	–	–
DEMAND LOAD (A)	59	TOTAL	21150	–	–	–	–	–	–	–	–	–	–

issued for:		
	ADDENDUM NO. 2	07-14-2015
	BIDS & PERMITS	06-26-2015
	80% OWNER REVIEW	06-22-2015

PROPOSED INTERIOR REMODEL FOR:

Kroger

STORE NO. D-361

425 N. CENTER STREET
NORTHVILLE, MI 48167

THE KROGER CO. OF MICHIGAN

jeffery a. scott architects p.c.
32316 grand river ave. suite 200
farmington, michigan 48336-3261
(248) 476-8800 fax (248) 476-8833

PANEL SCHEDULES

project no. 15100

sheet no. E6.2.1.1

PLOT FULL SIZE = 30"x42"

copyright © 2015