



- NOTES:**
1. CONTRACTOR TO ADD ELBOWS IN BRANCHLINES TO AVOID OBSTRUCTIONS AS NECESSARY TO KEEP SPRINKLER HEADS AT THE PROPER ELEVATION.
 2. HANGER #5 TYPICAL FOR ALL NEW SPRINKLER PIPING 1/2" AND SMALLER. UNLESS NOTED OTHERWISE.
 3. HANGER #6 TYPICAL FOR ALL NEW SPRINKLER PIPING BELOW CONCRETE. UNLESS NOTED OTHERWISE.
 4. HANGER #5 TYPICAL FOR ALL NEW SPRINKLER PIPING IN TOWERS AND CANOPIES HUNG FROM LIGHT GAUGE STEEL STRUCTURE. REF 4-F-4.
 5. HANGER #5 TYPICAL FOR ALL NEW SPRINKLER PIPING 6" AND LARGER. UNLESS NOTED OTHERWISE.
 6. ALL ARMORERS TO BE 1" PIPING U.O.
 7. PIPING ELEVATION TO BE FIELD VERIFIED BY INSTALLING CONTRACTOR.
 8. COORDINATE EXACT LOCATION OF SPRINKLERS AT COOLERS/FREEZERS WITH LIGHTS, THERMOSTATS AND THERMISTORS. SEE DRAWINGS. NOTE THAT FINAL LIGHT AND EVAPORATOR LOCATIONS MAY DIFFER FROM THOSE SHOWN ON PLAN.
 9. ADDITIONAL HEADS MAY BE REQUIRED, TYPICAL FOR ALL COOLERS/FREEZERS.
 10. ALL NEW PIPE FITTINGS TO BE:
 - a. 1/2" PIPING - 1/2" PIPING ROUNDED SCREWED
 - b. 1 1/2" - 6" PIPING - FLEXIBLE GROoved
 11. SEE PLAN FOR PROPOSED LOCATIONS



ALL ARM-OVER PIPING TO BE 1" SCHED-40
UNLESS NOTED OTHERWISE