



PARTITION TYPE NOTES:

- SEE ROOM FINISH SCHEDULE A6.2, DECOR DRAWINGS AND SPECIFICATIONS FOR FINISHES AND ADDITIONAL INFORMATION.
- ALL FULL HEIGHT, FREE STANDING WALLS, WALLS WITH ITEMS RECESSED INTO THEM, AND WALLS WITH RECESSED ELECTRIC PANELS, PIPING, & RESTROOM FIXTURES SHALL BE 6" MTL FRAMING. BALANCE OF METAL FRAMING SHALL BE 3-5/8" METAL FRAMING UNLESS INDICATED OTHERWISE.
 - WHEN ALIGNING WITH EXISTING WALL FURRING, WALL FURRING TO MATCH EXISTING.
- METAL FRAMING SHALL BE 24" ON CENTER (U.N.O) WITH HORIZONTAL BRACING PER MANUFACTURE SPECIFICATION.
 - WALLS THAT RECEIVE FRP FINISH SHALL BE FRAMED AT 16" ON CENTER.
 - WALLS THAT HAVE CEMENT BOARD SHEATHING SHALL BE FRAMED 16" ON CENTER.
- DRYWALL SHALL BE AS INDICATED ON PARTITIONS UNLESS MATCHING AND ALIGNING WITH AN EXISTING WALL / WALL INFILL, THAN IT WILL MATCH EXISTING.
- FURRING ON COOLERS AND CMU WALLS SHALL RUN VERTICAL.
- PROVIDE SLIP-TRACK/RECEIVER AT THE TOP OF ALL PARTITIONS SUBJECT TO STRUCTURAL DEFLECTION PER GYPSUM BOARD MANUFACTURES REQUIREMENTS.
- GYPSUM BOARD: TYPICAL 1/2" GYP. BOARD TO BE USED UNLESS NOTED OTHERWISE. REMODEL PROJECTS USE 5/8" GYPSUM BOARD WHERE EXISTING 5/8" GYPSUM BOARD IS IN PLACE.
- MOISTURE RESISTANT GYPSUM BOARD: 1/2" THICK TO BE USED UNLESS NOTED OTHERWISE.
- CEMENT BOARD: 1/2" UNLESS NOTED OTHERWISE.
- BRACING AT COOLER/FREEZER: FULL HEIGHT WALLS BUILT ALONG COOLER/FREEZER PANELS SHOULD BE BRACED AT ROOF PANEL TO UTILIZE STANDARD DEPTH METAL STUD.
- FLOOR FINISH AND BASE: REFER TO INTERIOR DECOR PLANS & ROOM FINISH SCHEDULE.
- FINISHED CEILINGS: EXTEND GYP. BD. 6" ABOVE CEILING, METAL STUDS DO NOT NEED TO EXTEND TO DECK (UNLESS) IF BRACED BACK TO STRUCTURE ABOVE AT 48" O.C. MAX.
- PROTECTIVE PANELING (WAINSCOT) TO BE TO 3'-6" AFF. IN RECYCLING ROOM PROVIDE 1/2" M.R. GYPSUM BOARD, EXCEPT BEHIND FRP. FRP IN RECYCLING ROOM TO OCCUR ONLY BEHIND THE TOMRA UNITS & IN THE STORAGE/MOP ROOM. FRP TO BE 5'-0" AFF BEHIND THE TOMRA UNITS. PROVIDE CEMENT BOARD BEHIND FRP TO 4'-0" AFF. WALLS WITH WAINSCOT EXPOSED TO CART TRAFFIC TO TYPICALLY RECEIVE TWO BUMPER RAILS. CENTER OF BUMPERS TO BE AT 6 1/4" AFF & 2'-6" AFF.

BIDS & PERMITS
80% OWNER REVIEW

06-28-2015
06-22-2015

PROPOSED INTERIOR REMODEL FOR:

Kroger

STORE NO. D-361

425 N. CENTER STREET
NORTHVILLE, MI 48167

THE KROGER CO. OF MICHIGAN

jeffery a. scott
architects p.c.

32316 grand river ave. suite 200
farmington, michigan 48336-3261
(248) 476-8800 fax (248) 476-8833

PARTITION TYPES

project no. 15100 sheet no. A3.2

copyright © 2015