This file was Created on 9/8/2023 @ 11:37:45 AM for D361 by CJ14810.

QUANTITY	NAME	STATUS	ELECTRICAL REQUIREMENTS
1	AUAS	RELO	120V, 10A MIN. DEDICATED CIRCUIT FOR ENTERPRISE SELF-CHECKOUT ATTENDANT STATION
1	E38AS	RELO	120V 500W DEDICATED CIRCUIT FOR POS EQUIPMENT FOR SCO ATTENDANT STATION
1	E38TP	RELO	375W FOR THERMAL PRINTER
1	GE156	RELO	120V 250W ELEC FED FROM RACEWAY FOR EFT PIN PAD & CREDIT CARD READER
1	GE38S	RELO	29W (DEDICATED CKT) FOR POS TERMINAL. WIRED TO KROGER SUB PANEL (NOT STARBUCKS PANEL)
1	GE38	RELO	120V 500W FOR REGISTER (DEDICATED CKT) 720W DEDICATED CIRCUIT W/ ISOLATED GROUND RECEPTACLE FOR USCAN UPS. ADDITIONAL QUAD OUTLET (86W TOTAL) ON A SEPARATE CIRCUIT FOR EAS DEACTIVATOR, CATALINA PRINTER, AND LANE LIGHT. SEE MANUFACTURER INSTALLATION GUIDE
3	ARU4C	RELO	FOR EXACT PLACEMENT OF OUTLETS.
3	D23T	RELO	120V 1PH .75AMPS FOR SERVICE SCALE/UPC PRINTER (TOLEDO), PROVIDE A 3/4" COND. TO ECR ROOM
1	BVSD8HP	RELO	35W FOR FANS, 52.4W FOR LIGHTS ON 6' FIVE-DECK DELI CASE MOUNT J.B. 1'-6" AB FL
1	FSDN8HP	RELO	35W FOR FANS, 43W FOR LIGHTS ON 8' 5-DECK NARROW FLORAL CASE
1	D195-5	RELO	120V, 17.4AMP, 1PH FOR CLICK LIST SOLID BACK HOT HOLDING CABINET. CABINET COMES FROM MANUFACTURER WITH CORD AND (NEMA 5-20P) TYPE PLUG SET.
2	D299TV-48	NEW	120V, 180W, 1PH, FOR 48" DIGITAL MONITOR FOR DELI MENU BOARD. DATA JACK REQUIRED PER UNIT.
1	D77B	NEW	120V, 1550W, 1PH FOR RICE COOKER
1	D77B	RELO	120V, 1550W, 1PH FOR RICE COOKER
1	DCKSO6AT	RELO	208V, 1PH, 3120W FOR HEAT LAMPS, 208V, 1PH, 4118W FOR DROP-IN WARMER, 208V, 1PH, 780W FOR HEATED DRAWERS, 120V, 1PH, 32W FOR LIGHTING
1	DM2THF6AM	NEW	120/208V,1PH REQUIRES MINIMUN 38 AMPS MAXIMUM 50 AMPS FOR 6' TWO TIER MOBILE HOT FOOD
4	D1DSC4HP	RELO	120V, 8.6AMP, 1PH CIRCUIT FOR 4'X4' (SELF-CONT) REF. MOBILE MERCHANDISER SUPPLIED WITH CORD & NEMA L5-15 TWIST LOCK PLUG.
1	DCFMD8HC	NEW	120V, 16W FOR FANS, 54W FOR LED LIGHTS FOR 8' MDLP SELF SERVICE IN LINE COLD FOOD CASE
2	DGD8HI	NEW	120V, 32W FOR FANS, 47.7W FOR MULLION LIGHTS, FOR 8FT GLASS DOOR DELI CASE.
1	DMDLR4HC	RELO	120V, 16W, FOR FANS, 31W, FOR LED LIGHTS, FOR 4' FRESH SLICED MULTI DECK CASE (REMOTE)
1	DMDLR6HC	RELO	120V, 24W, FOR FANS, 31W, FOR LED LIGHTS, FOR 6' FRESH SLICED MULTI DECK CASE (REMOTE)
1	DPSSUST6B-2	RELO	168W FOR FANS, 132W FOR LIGHTS, 38W FOR ANTI-SWEAT HEATERS FOR 6' SUSHI PREP/DISPLAY CASE W/ REF. REAR STORAGE
1	DS12HE	NEW	30W FOR FANS, 135W FOR AMB FANS, 1200W A/S HTRS, 257W FOR LIGHTS
1	DS8HE	RELO	20W FOR FANS, 90W FOR AMB FANS, 800W A/S HTRS, 177W FOR LIGHTS
1	GM20SS	NEW	120V,2AMP, 1PH CIRCUIT FOR LED LIGHTING IN 4' TOBACCO FIXTURE WITH NEMA5-15P PLUG.
1	GM208S	NEW	120V,4.25 AMP, 1PH CIRCUIT FOR LED LIGHTING IN 12' TOBACCO FIXTURE WITH NEMA5-15P PLUG
1	GM7M-3S	NEW	120V, 79.2W, FOR 3 FT KPNR/OTC LIGHT VALANCE (STARTER)
8	GM7M-3	NEW	120V, 79.2W, FOR 3 FT KPNR/OTC LIGHT VALANCE
5	E102	RELO	56W FOR THINCLIENT & MONITOR
1	E12C	RELO	960W FOR LASER PRINTER (GENERAL USE)
1	E18V	RELO	1200W FOR KROGER ATM
1	E42-17	RELO	120V, 37W, 1PH FOR 19" LED COMPUTER MONITOR
1	F41	NEW	SEE KROGER A&E STANDARDS FOR WHERE PLUGMOLD IS REQUIRED
1	GE155-K	RELO	120V, 12AMP, 1PH FORKEY ME KIOSK
1	GE186	RELO	120V 1PH 14AMPS FOR MICROWAVE MOUNT RCPT 4'-0" AB. FL.
1	GE2C	RELO	600W FOR INSTANT LOTTERY TICKET VENDING MACHINE
1	GE41	NEW	SEE KROGER A&E STANDARDS FOR WHERE PLUGMOLD IS REQUIRED
1	GR05C-60	RELO	1334W FOR 60 CU. FT. INDOOR ICE MERCHANDISER (S/C) AND 127W FOR CONDENSATE EVAPORATOR, WIRED SEPERATELY
1	C27TM	RELO	120V, 2AMP, 1PH CIRCUIT FOR 27" PICKUP TRAFFIC VIEW MONITOR WITH WALL MOUNT KIT
1	CSSMCOK	RELO	120V, 1.25AMP, 1PH CIRCUIT FOR 55" MONITOR WITH CORNER MOUNT KIT
1	P1DSC55J_CM	RELO	208V,18.8AMP, 1PH FOR 5'X5' REFRIGERATED PROMO CASE (SELF-CONT) UNIT COMES WITH 10' CORD AND L6-20P NEMA PLUG.
1	PGD8HI	NEW	120V, 32W FOR FANS, 47.7W FOR MULLION LIGHTS, FOR 8FT GLASS DOOR PRODUCE CASE.
4	PMSC6M-3_SR	RELO	240V,9.5.5AMP, 1PH FOR 6' ULTRA FRESH BERRY CASE (SELF CONTAINED) UNIT COMES WITH 9' CORD AND L14-30P NEMA PLUG.
1	T6SC	NEW	1265W FOR 6' TABLE W/REF BASE (SELF- CONT.)

This file was Created on 9/8/2023 @ 11:37:44 AM for D361 by CJ14810.

QUANTITY	NAME	STATUS	ADDITIONAL REQUIREMENTS
1	AUAS	RELO	3 DATA JACKS + SWITCH
1	E38AS	RELO	3 DATA, 1 VOICE JACK
1	GE156	RELO	IF PART OF CHECKSTAND OR AUAS STAND (1 DATA PATCH); OTHERWISE (1 DATA JACK)
1	GE38S	RELO	1 DATA, 1 VOICE JACK REQUIRED
1	GE38	RELO	IF PART OF CHECKSTAND OR AUAS STAND (1 DATA PATCH); OTHERWISE (1 DATA JACK, 1 VOICE JACK)
3	ARU4C	RELO	2 DATA JACKS
3	D23T	RELO	1 DATA JACK
2	D299TV-48	NEW	1 DATA JACK
5	E102	RELO	1 DATA JACK
1	E18V	RELO	1 VOICE JACK

issued for: BIDS AND PERMITS 12/13/2023
90% OWNER REVIEW 10/26/2023

PROPOSED MINOR INTERIOR REMODEL FOR:

STORE NO. D-361

425 N CENTER ST
NORTHVILLE, MI 48167

THE KROGER CO. OF MICHIGAN

jeffery a. scott architects p.c.
32316 grand river ave. suite 200
farmington, michigan 48336-3261
(248) 476-8800 fax (248) 476-8833

EQUIPMENT SCHEDULE

project no. 23101

sheet no. E6.1

PLOT FULL SIZE ● 30"x42"

copyright © 2023