


1. REFER TO NOTES ON SHEET P5.1.
2. PROVIDE NEW PLUMBING SERVICES TO FIXTURES AS INDICATED ON PLUMBING FIXTURE SCHEDULE (RE: P5.1).
3. WHERE MULTIPLE DRAINAGE FIXTURES ARE SERVED BY A SINGLE HUB DRAIN, PROVIDE CONCENTRIC 4" COUPLING ON HUB OPENING.
4. REFER TO PLUMBING DETAILS ON SHEET P5.1.
5. REFER TO ENLARGED PLUMBING PLAN ON SHEET P4.1.

- ① PROVIDE NEW 3" HUB DRAIN PER PSD-1 (RE: P5.1).
- ② VERIFY EXACT LOCATION OF EXISTING 3" HUB DRAIN. REUSE FLOOR DRAINAGE FIXTURE FOR NEW OR RELOCATED REFRIGERATED CASE.
- ③ ADJUST FLOOR DRAIN TO BE FLUSH WITH NEW FLOOR HEIGHT
- ④ PROVIDE 1/2" FW FROM NEW RO SYSTEM IN BACK NEAR ICE MACHINE. ROUTE IN OPEN CEILING TIGHT TO EXISTING STRUCTURE TO DROP DOWN IN WALL TO PRODUCE MISTING SYSTEM. PROVIDE WITH 1/2" FV VALVE ON TOP OF PRODUCE CASE.
- ⑤ PROVIDE 3/4" HW FROM EXISTING HW LINE IN OPEN CEILING. ROUTE IN OPEN CEILING TIGHT TO EXISTING STRUCTURE TO DROP DOWN IN CHASE/WALL ABOVE CASE. INSTALL NEW HOSE BIBB PER PSD-21 (RE:5.1)



copyright © 2024