

VENDOR BID KEYNOTES:

1. NOT USED
2. NOT USED
3. OEM TO PROVIDE CASES WITH DUAL-TEMPERATURE CONTROL KITS AND SWITCH INSTALLED
4. FIXTURE(S) SHALL BE ORDERED AND PURCHASED SEPARATELY BY THE KROGER PROJECT MANAGER
5. NOT USED
6. CASE END GUARDS SUPPLIED BY MANUFACTURER

INSTALLER GENERAL NOTES:

- LOCATIONS OF PVC RISERS FOR THE ROUTING OF REFRIGERATION LINES SHOWN ON PLAN. ALTERNATE ROUTING MAY BE REQUIRED. FIELD CONDITIONS TO BE VERIFIED FOR CONFLICTS. CARE SHOULD BE TAKEN IN ROUTING OF LINES TO MINIMIZE INTERFERENCE WITH SKYLIGHT OPENINGS. REFRIGERATION LINES SHALL BE ROUTED AS HIGH AS PRACTICAL.
- EXISTING REFRIGERATION PIPING TO BE REAPPLIED WHERE PRACTICAL. IT'S THE INSTALLER'S RESPONSIBILITY TO REPLACE EXISTING PIPING AND INSULATION AS REQUIRED TO CONFORM TO THE REFRIGERATION CONDENSING EQUIPMENT MANUFACTURER'S RECOMMENDATIONS FOR THE REFRIGERATION LOAD SERVED.

INSTALLER KEYNOTES:

A. NOT USED
B. LOCATION OF REFRIGERATION PIPING RISER, REFERENCE RISD-36 & RISD-36A
C. INSTALL SELF-CONTAINED EQUIPMENT
D. NOT USED
E. INSTALL CASE END GUARDS SUPPLIED BY MANUFACTURER
F. NOT USED
G. NOT USED
H. NOT USED

CONTROL NOTE:

- ANY NEW CIRCUIT CONTROLS REQUIRED TO ACCOMPLISH REMODEL TO BE SIZED AND PROVIDED BY REFRIGERATION INSTALLER. SUITABILITY OF RETAINING EXISTING CONTROLS FOR MODIFIED SYSTEMS TO BE CONFIRMED BY REFRIGERATION INSTALLER. VERIFY: VALVE PRESSURE DROPS AND OPERATION WHEN NEW LOADS DIFFER FROM EXISTING. CONTROLS TO BE INSTALLED IN ACCESSIBLE LOCATIONS PROTECTED FROM DAMAGE.

SHEET INDEX:

R1.1 (THIS SHEET) REFRIGERATION EQUIPMENT PLAN
R1.2 NOT USED
R5.1 REFRIGERATION STANDARD DETAILS
R6.1 REFRIGERATION EQUIPMENT SCHEDULE

LEGEND:

TS TEMPERATURE SENSOR
DT DEFROST TERMINATION THERMOSTAT

GENERAL NOTES :

ALL EQUIPMENT IS TO BE CONSIDERED UNLESS NOTED OTHERWISE THE FULL EXTENT OF EXISTING, NEW, AND/OR RELOCATED EQUIPMENT SHALL BE CONSIDERED IN THE CONTRACT. REFER TO ARCHITECTURAL PLANS FOR ADDITIONAL INFORMATION FOR THIS PLAN. INFO. TAKEN FROM ARCHITECTURAL PLANS DATED _____ AND KROGER PLANS DATED _____ ENCLOSED UPDATED FOR ACTUAL CONDITIONS. CONTACT THE KROGER PROJECT MANAGER FOR ANY DISCREPANCIES.

NOTE:
THIS DRAWING IS INTENDED ONLY TO SHOW THE REQUIREMENTS OF THE KROGER CO. ALL WORK SHOWN ON THIS DRAWING SHALL BE PERFORMED IN ACCORDANCE WITH ALL REGULATIONS, ORDINANCES AND APPROVAL OF THE INSPECTION AUTHORITIES HAVING JURISDICTION. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO OBTAIN ALL PERMITS AND APPROVALS. THE CONTRACTOR IS RESPONSIBLE FOR ALL CONSTRUCTION METHODS AND SAFETY PRECAUTIONS REQUIRED TO PERFORM THE WORK. THE CONTRACTOR IS RESPONSIBLE FOR THE ACCURACY OF THE CONTRACT DOCUMENTS AND FIELD CONDITIONS AND SHALL REPORT ANY DISCREPANCIES TO THE KROGER PROJECT MANAGER BEFORE PROCEEDING WITH THE WORK.

MICHIGAN
(EXIST) BOUNTIFUL P & P
40395 GRAND RIVER AVENUE
NOVI, MICHIGAN
PHONE (248) 957-2254 FAX (248) 957-2255

FRESH FOR EVERYONE™ Kroger

GENERAL OFFICE
FACILITY ENGINEERING
1014 VINE ST. CINCINNATI, OHIO 45202
PH (513) 762-1487 FAX (513) 762-4012

MINOR WITHIN THE WALLS

D-406
1200 E BRISTOL RD
BURTON, MI 48529

CURRENT PLAN DATE: 3/13/2024
ORIGINAL PLAN DATE: 7/12/2023
DRAWN: D. GRIESSMANN
CHECKED:

REVISIONS

DS	09/15/23	KDG	03/13/24								

STANDARD PLOTTED SCALE: 3/32" = 1'-0"

BUILDING STATS:

TOTAL SHELVING	2,530 LF
SALES AREA % OF GROSS BUILDING	39,393 SF 72 %
BASE STORE	51,902 SF
MEZZANINE	1,013 SF
DOCK / UTILITY	1,476 SF

GROSS BUILDING 54,391 SF

REFRIGERATION EQUIPMENT LAYOUT

STEEL PACKAGE ID:

D-406

SHEET: R1.1

CAD FILE:

- FOR REFERENCE ONLY -