

(EXISTING) LP-LPD													
208Y/120V			225A BUS		3PH	4W	MLO	SURFACE					
POLE	TYPE	TRIP	WIRE	CND	DESCRIPTION	LTG	RECP	KIT	SPC HEAT	SPC COOL	HTRS	ELEV	MISC
1	20	EXISTING			OTC LIGHT VALANCE	1200							
3	20	EXISTING			SEAFOOD TRACK LIGHT	1200							
5	20	EXISTING			EX MISC LTG	1200							
7	20	EXISTING			EX MISC LTG	1200							
9	20	EXISTING			WINE RACK LIGHTING	1200							
11	20				SPARE								
13	20	EXISTING			MISC LIGHTING	1200							
15	20	EXISTING			VALANCE LIGHTING	1200							
17	20				SPARE								
19	20	EXISTING			ISLAND CASE LIGHTING	1200							
21	20	EXISTING			ISLAND CASE LIGHTING	1200							
23	20	EXISTING			MISC LIGHTING	1200							
25	20	EXISTING			MISC LIGHTING	1200							
27	20	EXISTING			MISC LIGHTING	1200							
29	20	EXISTING			MISC LIGHTING	1200							
31	20	EXISTING			PRODUCE TRACK LIGHTING	1200							
33	20	EXISTING			PRODUCE TRACK LIGHTING	1200							
35	20	EXISTING			FLORAL/SEATING LIGHTING	1200							
37													
39	20	2#10+1#10GRD	3/4		VALANCE LIGHTS	1200							
41	20	2#10+1#10GRD	3/4		VALANCE LIGHTS	1200							
2	20	EXISTING			MISC LIGHTING	1200							
4	20	EXISTING			WINE TRACK LIGHTING	1200							
6	20	EXISTING			WINE TRACK LIGHTING	1200							
8	20	EXISTING			WINE TRACK LIGHTING	1200							
10	20	EXISTING			WINE TRACK LIGHTING	1200							
12	20	EXISTING			MISC LIGHTING	1200							
14	20	EXISTING			KITCHEN PLACE TRACK LIGHTING	1200							
16	20	EXISTING			KITCHEN PLACE TRACK LIGHTING	1200							
18	20				SPARE								
20	20	EXISTING			SALES LIGHTING	1200							
22	20	EXISTING			PRODUCE TRACK LIGHTING	1200							
24	20	EXISTING			SUSHI TRACK LIGHTING	1200							
26	20	EXISTING			FLORAL TRACK LIGHTING	1200							
28	20	EXISTING			PRODUCE TRACK LIGHTING	1200							
30	20	EXISTING			PRODUCE TRACK LIGHTING	1200							
32	20	EXISTING			BACK HALLWAY LIGHTS	1200							
34													
36	20	EXISTING			TRACK LIGHTING	1200							
38	20	EXISTING			SALES LIGHTING	1200							
40	20	EXISTING			SALES LIGHTING	1200							
42	20	EXISTING			SALES LIGHTING	1200							
CONNECTED LOAD (VA)			44400			SUBTOTAL (VA)	44400	###	###	###	###	###	###
DEMAND LOAD (A)			55500			DEMAND TOTAL (VA)	1,000	1,000	1,000	1,25	1,00	1,00	
DEMAND LOAD (A)			154			TOTAL (VA)	55500	###	###	###	###	###	###

issued for:	BIDS AND PERMITS 90% OWNER REVIEW	01/31/2024 10/23/2023
<div>PROPOSED MINOR INTERIOR REMODEL FOR:</div> <div></div> <div>STORE NO. D-409 12731 S SAGINAW ST GRAND BLANC, MI 48439</div> <div>THE KROGER CO. OF MICHIGAN</div>		
<div><div>jeffery a. scott architects p.c.</div></div> <div>32316 grand river ave. suite 200 farmington, michigan 48436-3261 (248) 476-8800 fax (248) 476-8833</div>		
PANEL SCHEDULES		
project no.	sheet no.	
23042	E6.2.2	