


1. WHEN CASES ARE FED FROM LOOP PIPING, SUCTION STOP SOLENOIDS WILL BE ON REFRIGERATION CIRCUITS ON SALES FLOOR.
2. REFER TO PIPING DRAWINGS (R3, R4, R5) FOR EXACT LOCATIONS

1. REFER TO R-SERIES REFRIGERATION SHEETS.
2. REMOVE AND REINSTALL WIRELESS REFRIGERATION TEMPERATURE SENSORS AS DIRECTED BY KROGER.
3. UPON PROJECT CLOSEOUT, PROVIDE A FRAMED ARCHITECTURAL D-SIZE RECORD DRAWING, SUITABLE FOR WALL MOUNTING, DOCUMENTING THE INSTALLED ROUTING OF CASE CONTROLLER WIRING OVERLaid ON THE BUILDING PLAN.



Issued for:	BIDS AND PERMITS	01/31/2024
	90% OWNER REVIEW	10/23/2023


**PROPOSED MINOR INTERIOR
REMODEL FOR:**



STORE NO. D-409

12731 S SAGINAW ST
GRAND BLANC, MI 48439

THE KROGER CO. OF MICHIGAN



jeffery a.
scott
architects p.c.

32316 grand river ave. suite 200
farmington, michigan 48336-3261
(248) 476-8800 fax (248) 476-8833

ENERGY MGMT TERM PLAN

project no.	sheet no.
-------------	-----------

[illegible]

23042	FM-2
-------	------

PLOT FULL SIZE • 30"x42"

copyright © 2024