

Luminaire Schedule									
Type	Description	Manufacturer / Series	Housing / Mounting	Lamp Qty	Lamp Type	Ballast / Driver	Finish	Comments	Fixture Load

ELECTRIC LEGEND			ELECTRIC LEGEND			ELECTRIC LEGEND		
SYMBOL	DESCRIPTION		SYMBOL	DESCRIPTION		SYMBOL	DESCRIPTION	
LIGHTING AND LIGHTING CONTROLS			MISCELLANEOUS			WIRE / CABLE / RACEWAY		
	LUMINAIRE (REFER TO THE LUMINAIRE SCHEDULE) NOTE THAT OTHER SHAPES MAY ALSO BE USED TO REPRESENT LUMINAIRES			LOW VOLTAGE THERMOSTAT (LEFT) AND TEMPERATURE SENSOR (RIGHT)			BRANCH CIRCUIT HOME RUN WITH PANEL NAME AND CIRCUIT NUMBER(S)	
	SHADED LUMINAIRES DENOTE THOSE CONNECTED TO EMERGENCY OR STANDBY POWER AS APPLICABLE (UNSWITCHED LUMINAIRES ARE EGRESS LIGHTS AND/OR NIGHT LIGHTS THAT OPERATE 24/7)			LINE VOLTAGE THERMOSTAT (LEFT) AND REVERSE ACTING THERMOSTAT (RIGHT)			CABLING / RACEWAY INSTALLED CONCEALED IN WALLS OR ABOVE CEILING	
	TRACK LIGHTING IN LENGTH SHOWN AND WITH NUMBER OF LUMINAIRE HEADS AS INDICATED PROVIDE ALL REQUIRED ACCESSORIES (FITTINGS, END CAPS, POWER FEEDS, ETC.)			HUMIDITY STAT (LEFT) AND HUMIDITY SENSOR (RIGHT)			CABLING / RACEWAY INSTALLED BELOW FLOOR OR GRADE	
	CEILING FAN			PRESSURE STAT (LEFT) AND PRESSURE SENSOR (RIGHT)			CABLE TRAY	
	SINGLE / DOUBLE SIDED EXIT SIGN CONNECT AHEAD OF SWITCHING & CONFIGURE ARROWS TO INDICATE DIRECTION OF EGRESS TRAVEL			ANSUL MANUAL PULL STATION (REFER TO SPECIFICATION 2605M.00 FOR REQUIRED WORK)			FEEDER DUCT / BUS DUCT	
	EMERGENCY LIGHTING UNIT WITH 90 MINUTE BATTERY BACKUP AND ASSOCIATED REMOTE HEADS WHERE APPLICABLE, CONNECT TO LOCAL LIGHTING CIRCUIT AHEAD OF SWITCHING			INDICATES DIRECT CONNECTION TO EQUIPMENT			JUNCTION BOX ABOVE ACCESSIBLE CEILING	
	OUTDOOR AREA SITE LIGHTING STANDARD NUMBER OF LUMINAIRE HEADS AS INDICATED ON DRAWINGS			MOTOR			JUNCTION BOX AT OVERHEAD STATIONARY WORK AREAS WITH NO CEILING	
	A = LUMINAIRE TYPE "A" - NIGHT LIGHT (UNSWITCHED), "S" = SWITCHING DESIGNATION EL = EGRESS LUMINAIRE (ILLUMINATES PATH OF EGRESS, UNSWITCHED UNLESS OTHERWISE NOTED)			VARIABLE FREQUENCY DRIVE / VARIABLE SPEED DRIVE			FLUSH MOUNTED JUNCTION BOX OR PULL BOX AS APPLICABLE FOR APPLICATION	
	LIGHTING SWITCH (KEYS: 2 = 2-POLE, 3 = 3-WAY, 4 = 4-WAY, D=DIMMER, K=KEYED, T = TIMER SWITCH, M = MOMENTARY CONTACT, P = SWITCH W/PILOT LIGHT)			ENCLOSED CIRCUIT BREAKER			FLUSH MOUNTED PULL BOX	
	CEILING MOUNTED OCCUPANCY SENSOR - DUAL TECHNOLOGY UNLESS OTHERWISE NOTED BY TYPE TYPE "IR" = INFRARED, TYPE "US" = ULTRASONIC			COMBINATION DISCONNECT SWITCH AND MAGNETIC STARTER W/ PILOT LIGHT, AUXILIARY CONTACTS AND I.C.A. SWITCH			MANHOLE	
	WALL MOUNTED OCCUPANCY SENSOR SWITCH - DUAL TECHNOLOGY UNLESS OTHERWISE NOTED BY TYPE TYPE "IR" = INFRARED, TYPE "US" = ULTRASONIC			MOTOR			UTILITY POLE	
	PHOTOCELL LIGHT SENSOR - PHOTO SENSOR			VARIABLE FREQUENCY DRIVE / VARIABLE SPEED DRIVE			SINGLE-SERVICE SURFACE RACEWAY (ONE COMPARTMENT - POWER)	
	LIGHTING CONTROL PANEL			LINE VOLTAGE MOTOR OPERATED DAMPER			MULTI-SERVICE SURFACE RACEWAY (TWO COMPARTMENT - POWER AND TECHNOLOGY)	
	LIGHTING CONTROL DIGITAL SWITCH OR CONTROL INTERFACE: "KEY" DENOTES SWITCH DESIGNATION DETAILED ON DRAWINGS			EMERGENCY-POWER-OFF (EPO) PUSHBUTTON STATION WITH DESCRIPTIVE ENGRAVED PLATE AND MEANS TO PREVENT ACCIDENTAL ACTIVATION			SURFACE RACEWAY WITH INTEGRAL RECEPTACLES ("PLUGSTRIP")	
	LIGHTING CONTROL SYSTEM - CEILING MOUNTED INFRARED RECEIVER/SENSOR			CONTROL STATION WITH DESCRIPTIVE ENGRAVED PLATE			SERVICE POLE - POWER AND TECHNOLOGY WHERE APPLICABLE	
	AUTOMATIC LOAD CONTROL RELAY DEVICE			TIME CLOCK FOR PROGRAMMABLE TIME-OF-DAY AND EXTENDED CONTROL			CONDUIT UP OR DOWN	
	EMERGENCY LIGHTING TRANSFER SWITCH DEVICE - 20A BRANCH CIRCUIT RATED			ENCLOSED RELAY		ABBREVIATIONS		
				CONTRACTOR		42"	DISTANCE ABOVE FINISHED FLOOR / GRADE / PAVEMENT	
				HAND DRYER		AF	AMP FRAME OF FUSED SWITCH OR CIRCUIT BREAKER	
				PLW/WOOD ELECTRICAL SWITCHBOARD OR SWITCHGEAR (DIMENSIONS MAY VARY)		AFCI	ARC FAULT CIRCUIT INTERRUPTER	
				ELECTRICAL PANELBOARD OR DISTRIBUTION BOARD (DIMENSIONS MAY VARY) / FLUSH OR SURFACE MOUNTED AS INDICATED)		AT	AMP TRIP OF FUSED SWITCH OR CIRCUIT BREAKER	
				DIT TYPE TRANSFORMER - FLOOR MOUNTED ON CONCRETE PAD (LEFT), SUSPENDED FROM CEILING OR WALL (RIGHT)		ATS	AUTOMATIC TRANSFER SWITCH	
				EPO FILLED TRANSFORMER		BAS	BUILDING AUTOMATION SYSTEM	
				CONCRETE FILLED STEEL BOLLARD		C.T.C.	WORK UNDER DIVISION 27 OR 28 AS APPLICABLE	
				GROUND ROD - ROD ONLY (LEFT), WITH INSPECTION WELL (RIGHT)		C/B	CIRCUIT BREAKER	
RECEPTACLES AND MISCELLANEOUS OUTLETS			SINGLE LINE DIAGRAM			C/CH	COUNTER HEIGHT OR SPECIAL HEIGHT DEVICE	
	SINGLE (SIMPLEX), DUPLEX AND DOUBLE DUPLEX (QUAD) RECEPTACLE RESPECTIVELY			ELECTRIC UTILITY COMPANY AND ASSOCIATED CURRENT TRANSFORMERS		DW	DISHWASHER	
	RECEPTACLES ON EMERGENCY OR STANDBY POWER CIRCUIT DIAMOND OUTLINE MAY BE APPLIED TO ANY SPECIALTY RECEPTACLE SYMBOL			CUSTOMER ELECTRIC METER AND ASSOCIATED CURRENT TRANSFORMERS H = HIGH DENSITY METERING CABINET/BANK MOUNTED TO TIGHTLY GROUP ALL METERS TOGETHER		E	EMERGENCY	
	GFI / GFCI RECEPTACLES			GROUNDING ELECTRODE PER NFPA TO ARTICLE 250 MINIMUM		EAS	EMERGENCY MANAGEMENT SYSTEM	
	SURGE PROTECTIVE DEVICE RECEPTACLES			ENCLOSED CIRCUIT BREAKER		EPO	EMERGENCY POWER OFF	
	ISOLATED GROUND RECEPTACLES			HEAVY DUTY DISCONNECT SWITCH (NON-FUSED/LEFT) (FUSED/RIGHT) SIZES MAY BE SHOWN ONLY IN SCHEDULE		ER	EQUIPMENT ROOM	
	RECEPTACLES WITH USB OUTLETS			ELECTRICAL PANELBOARD OR DISTRIBUTION BOARD		ERM	ENERGY REDUCTION MAINTENANCE SWITCH	
	HALF SWITCHED RECEPTACLES			ELECTRICAL SWITCHBOARD OR SWITCHGEAR		ESP	EMERGENCY STANDBY RATING	
	FULL SWITCHED RECEPTACLES			AUTOMATIC TRANSFER SWITCH		ETR	EXISTING TO REMAIN	
	REGRESSED ("CLOCK HANGER") RECEPTACLES			SURGE PROTECTIVE DEVICE		EWG	ELECTRIC WATER COOLER EXISTING	
	CEILING MOUNTED RECEPTACLES		ENVIRONMENTAL CONTROLS AND ALARMS			FBO	FURNISHED BY OTHERS - INSTALLED AND WIRED BY E.C.	
	FLOOR OUTLET - POWER AND / OR TECHNOLOGY			CARBON MONOXIDE ALARM DEVICE - MULTI-STATION		FIBO	FURNISHED AND INSTALLED BY OTHERS - TYP	
	SPECIAL PURPOSE RECEPTACLE			VOLATILE ORGANIC COMPOUNDS (VOC) SENSOR (MONITORED BY ENVIRONMENTAL CONTROL PANEL)		FP	RECEPTACLE TO BE USED FOR A FLAT PANEL DISPLAY	
	POWER WHIP CONNECTION TO SYSTEM FURNITURE			CARBON MONOXIDE SENSOR (MONITORED BY ENVIRONMENTAL CONTROL PANEL)		FWE	FURNISHED WITH EQUIPMENT BY OTHERS - INSTALLED AND WIRED BY E.C.	
	CEILING DUPLEX RECEPTACLE WITH ADJACENT REEL-MOUNTED DROP CORD			REFRIGERANT LEAK DETECTION SENSOR (MONITORED BY REFRIGERANT LEAK DETECTION CONTROL PANEL)		GD	GARABGE DISPOSAL	
	RECEPTACLE ATTRIBUTES 42" = MOUNT RECEPTACLE AT THIS HEIGHT ABOVE GRADE / FINISHED FLOOR C = INSTALL ABOVE COUNTER AND BACKSPLASH H = INSTALL RECEPTACLE HORIZONTALLY L = LT (PROVIDE ILLUMINATED FACE OR INDICATOR LIGHT TO INDICATE THERE IS POWER TO RECEPTACLE) SW = SPLIT WIRED T = TAMPER RESISTANT W = WEATHER PROOF WHILE IN USE COVER AND WEATHER RESISTANT RECEPTACLE			ENVIRONMENTAL AUDIO / VISUAL ALARM DEVICE - WALL CO = CARBON MONOXIDE, VOC = VOLATILE ORGANIC COMPOUND, M = METHANE, R = REFRIGERANT LEAKAGE		GFI	GROUND FAULT EQUIPMENT PROTECTION	
DOOR OPERATORS/DEVICES				ENVIRONMENTAL AUDIO / VISUAL ALARM DEVICE - CEILING / OVERHEAD MOUNTED CO = CARBON MONOXIDE, VOC = VOLATILE ORGANIC COMPOUND, M = METHANE, R = REFRIGERANT LEAKAGE		GFI	GROUND FAULT CIRCUIT INTERRUPTER DEVICE	
	SECURITY JUNCTION BOX - WALL MOUNT ABOVE ACCESSIBLE CEILING ON SECURE SIDE OF DOOR			DOOR BELL WITH TRANSFORMER & PUSHBUTTONS		GND	GROUND	
	ELECTRIC DOOR OPERATOR MANUAL (LEFT), AUTOMATIC (RIGHT)			FLUSH PUSHBUTTON FOR DOOR CHIME OR BELL		H.C.	WORK UNDER DIVISION 23	
	PUSH PLATE FOR MANUAL CONTROL OF ELECTRIC DOOR OPERATOR					"HAND - OFF" AUTO SWITCH		
	SINGLE ENTRANCE TYPE HORN DOOR SIGNAL AND TRANSFORMER WITH ASSOCIATED PUSHBUTTON(S)				ISC	ISOLATED GROUND SHORT CIRCUIT CURRENT		
	CEILING COMMUNICATION OUTLET - VOICE, DATA, DATA/VOICE RESPECTIVELY LEFT TO RIGHT - PROVIDE 4"x4" BOX WITH 1-GANG RING AND (1) 1" CONDUIT TO ABOVE ACCESSIBLE CEILING UNLESS NOTED OTHERWISE							
	2 ENTRANCE TYPE ELECTRIC DOOR CHIME AND TRANSFORMER WITH ASSOCIATED PUSHBUTTON(S)							
	DOOR BELL WITH TRANSFORMER & PUSHBUTTONS							
	FLUSH PUSHBUTTON FOR DOOR CHIME OR BELL							

ELECTRIC DESIGN CRITERIA

APPLICABLE BUILDING CODES

2017 OHIO BUILDING CODE (BASED ON THE INTERNATIONAL BUILDING CODE)
2017 NFPA 70 - NATIONAL ELECTRICAL CODE (NEC)
2012 INTERNATIONAL ENERGY CONSERVATION CODE (IECC)

TESTING/COMMISSIONING FOR LIGHTING CONTROLS

LIGHTING CONTROL DEVICES AND SYSTEMS SHALL BE TESTED TO ENSURE THE HARDWARE AND SOFTWARE IS CALIBRATED, PROGRAMMED, AND IN PROPER WORKING ORDER. INSTALLING CONTRACTOR SHALL BE RESPONSIBLE FOR ALL REQUIRED INSTALLATION REPORTS AND CERTIFICATES UNLESS COMMISSIONING IS BEING PERFORMED IN WHICH CASE THE COMMISSIONING PROVIDER SHALL BE RESPONSIBLE FOR ALL REPORTS, CERTIFICATES, ETC.) AND SHALL PROVIDE MANUALS FOR LIGHTING CONTROL DEVICES TO OWNER PRIOR TO PROJECT CLOSE-OUT. INSTALLING CONTRACTOR SHALL BE RESPONSIBLE FOR CONTRACTING WITH APPROPRIATE PARTIES TO ARRANGE FOR TESTING OF THE LIGHTING CONTROL SYSTEMS AND SHALL BE RESPONSIBLE FOR ENSURING ALL REQUIRED FUNCTIONAL PERFORMANCE TESTING FORMS/REPORTS ARE COMPLETED AND SUBMITTED TO THE OWNER AND LOCAL AIA PRIOR TO PROJECT CLOSE-OUT. FUNCTIONAL PERFORMANCE TESTING OF LIGHT CONTROLS SHALL FOLLOW THE REQUIREMENTS LISTED IN THE APPLICABLE ENERGY CODE INCLUDING BUT NOT LIMITED TO VERIFICATION OF THE PERFORMANCE OF OCCUPANCY SENSORS, AUTOMATIC TIME SWITCHES, AND DAYLIGHT HARVESTING CONTROLS.

ENERGY MANAGEMENT SYSTEM (EMS) LEGEND

(APPLIES ONLY FOR EMS DRAWING SHEETS)

SYMBOL	DESCRIPTION	NOTE	CABLE/CONDUCTORS
<div>DT</div>	DEFROST CONDUIT	PROVIDE OUTLET BOX AT CASE. PROVIDE WIRING FROM CASE TO RESPECTIVE DANFOSS "RC" PANEL. SEE DEFROST WIRING SCHEDULE. PROVIDE WIRING IN 1" CONDUIT FOR WALK-IN COOLERS/FREEZERS AND ALL OTHER APPLICATIONS. FOR REFRIGERATED CASES, PROVIDE WIRING FROM CASE TO RESPECTIVE SINGLE PHASE OR THREE PHASE CONNECTION POINT PER RSD-13 (WHERE APPLICABLE), OR DIRECTLY TO PROTOCOL UNIT. SEE DEFROST WIRING SCHEDULE FOR DEFROST CIRCUIT PHASE. IN ADDITION, PROVIDE 1" CONDUIT FOR KLUXON UNITS. KLUXON UNITS TO BE WIRED IN SERIES PER REFRIGERATION CIRCUIT WITH A SINGLE HOME RUN TO "RC" PER CIRCUIT.	SEE DEFROST WIRING SCHEDULE ON EMS SHEETS. REFER TO SPECIFICATION 26.06.19 FOR CABLEING REQUIREMENTS AND ADDITIONAL INFORMATION.
<div>SS</div>	SUCTION STOP SOLENOID	PROVIDE OUTLET BOX AT CASE. PROVIDE CABLE IN 1" CONDUIT FROM SOLINOID TO "RC" PANEL. "RC" CONTROL PANEL, SOLENOID SHALL BE FURNISHED & INSTALLED BY REFRIGERATION CONTRACTOR.	
<div>TS</div>	TEMPERATURE SENSOR (REFRIGERATION)	PROVIDE OUTLET BOX AT CASE. PROVIDE CABLE FROM SENSOR TO RESPECTIVE "RC" CONTROL PANEL. PROVIDE 1" CONDUIT FROM SENSOR TO PROVIDE CEILING. THEN FREE-WIRED TO "JOIST" SPACE. CABLE IN JOIST SPACE TO BE FREE-WIRED.	26.05.19 FOR CABLEING REQUIREMENTS AND ADDITIONAL INFORMATION. REFER TO REQUIREMENT INSTALLATION SPECS FOR FREE-WIRED REQUIREMENTS.
WHERE REFRIGERATION EQUIPMENT IS SERVED FROM A PROTOCOL UNIT, ROUTE TO RESPECTIVE PROTOCOL UNITS "RC" CONTROL PANEL.			
IN THE NOTES STATED ABOVE, PROVIDE SHALL MEAN FURNISH AND INSTALL.			
PROVIDE AND WIRE ALL ADDITIONAL CONTACTORS, RELAYS AND ADDITIONAL ENCLOSURES NECESSARY FOR A FULLY WORKING DEFROST SYSTEM.			