



- GENERAL NOTES**
- A. PROVIDE A MINIMUM OF (2) 1" CONDUITS FOR EACH REFRIGERATION CIRCUIT, CONSISTING OF (1) CONDUIT FOR LOW VOLTAGE AND (1) FOR LINE VOLTAGE.
- B. FURNISH AND INSTALL ALL WIRES AND CABLES. PROVIDE FINAL TERMINATIONS FOR ALL LINE VOLTAGE WIRES I.N.C. REFRIGERATION CONTRACTOR SHALL MAKE FINAL TERMINATIONS AT BOTH ENDS OF LOW VOLTAGE WIRES CABLES AND DEFROST WIRING. PROVIDE SUFFICIENT SLACK AT BOTH ENDS TO ALLOW FOR SERVICE LOOPS AND TO FACILITATE PROPER TERMINATIONS, ELSEWHERE, INCLUDING RELATED POWER WIRING SHOWN ON OTHER DRAWING SHEETS. PROVIDE ALL REQUIRED TERMINATIONS.
- C. IF A DISCREPANCY EXISTS BETWEEN THIS DRAWING AND THE SPECIFICATIONS, REFER TO KROGER PROJECT ENGINEER FOR RESOLUTION.
- D. WHERE APPLICABLE FOR ISLAND TYPE CASE LOCATIONS, INSTALL CONDUIT BELOW SLAB AND PROVIDE OUTLET BOXES SURFACE MOUNTED JUST ABOVE FLOOR SLAB.
- E. REFER TO EQUIPMENT SCHEDULES ON E&S DRAWINGS FOR MOUNTING HEIGHTS AND ADDITIONAL INFORMATION. ALSO SEE DETAILS ON SHEET ES SERIES DRAWINGS WHERE APPLICABLE.
- F. COORDINATE THE UNDERSLAB CONDUIT AND RACEWAY LAYOUT WITH ALL AFFECTED PARTIES PRIOR TO SLAB PLACEMENT.
- G. PROVIDE 10 FEET OF FLEXIBLE CONDUIT FOR REFRIGERATED CASES SERVED FROM WALL JUNCTION BOXES FOR CONNECTION TO CASES BY THE PHASE II EQUIPMENT CONTRACTOR.
- H. REFER TO ELECTRICAL DIMENSION PLANS FOR GENERAL DIMENSIONAL INFORMATION THAT SHALL SCHEMATICALLY APPLY FOR CORRESPONDING SYSTEMS WORK.

2 ENERGY MANAGEMENT PLAN AND DETAILS
3/32" = 1'-0"



KOHRIS LONNEMANN HEIL ENGINEERS, INC.

MECHANICAL/ELECTRICAL ENGINEERS

WWW.KLHENGRS.COM

1538 ALEXANDRIA PIKE, SUITE 111

FT. THOMAS, KENTUCKY 41075

800-354-9783

859-442-8690

859-442-8658 FAX

LEXINGTON, KENTUCKY

LOUISVILLE, KENTUCKY

COLUMBUS, OHIO

OWNERSHIP OF INSTRUMENTS OF SERVICE

All reports, plans, specifications, computer files, field data, notes and other documents and instruments prepared by the Consultant as instruments of service shall remain the property of the Consultant. The Consultant shall retain all common law, statutory and other reserved rights, including, without limitation, the copyright therein.

#	Date	Change Description

KROGER N641



2028 E HARBOR RD

PORT CLINTON, OH 43452

for

THE KROGER COMPANY



300 Spruce Street

Suite 300

Columbus, Ohio 43215

Phone: (614) 461-4684

Fax: (614) 290-8881

www.moodynolan.com

Dwg. Coord.: CJC	Tech. Coord.: JAT	Proj. #: 25835.00
------------------	-------------------	-------------------

ENERGY MANAGEMENT PLAN AND DETAILS	EM1.1
------------------------------------	-------

BID/PERMIT	12/13/2023
------------	------------