(EXISTING) RP-LG1

208Y/120V 200A BUS 3PH 4W MLO – RECESSED

POLE	TYPE	TRIP	WIRE	CND	DESCRIPTION	LTG	RECP	KIT	SPC HEAT	SPC COOL	HTRS	ELEV	MISC
1		20	EXISTING		RECEPTACLE		180						
3		20	EXISTING		RECEPTACLE		180						
5		20	EXISTING		RECEPTACLE		180						
7										1800			
9		30	EXISTING		ECR SPLIT UNIT					1800			
11		20	EXISTING		RECEPTACLE		180						
13		20	EXISTING		FLORAL PRINTER, RECEPTACLE		500						
15		20	EXISTING		REGISTER #8		500						
17		20			SPARE								
19		20	EXISTING		VENDING			1200					
21		20	EXISTING		VENDING			1200					
23		20	EXISTING		VENDING			1200					
25		20	EXISTING		VENDING			1200					
27		20	EXISTING		CORD REAL		720						
29		20	EXISTING		CORD REAL		720						
31		20			SPARE								
33		20			SPARE								
35		20			SPARE								
37		20			SPARE								
39		20			SPARE								
41		20	EXISTING		GM20SS, GM20BS		750						
2		20	EXISTING		REGISTER #6		500						
4		20	EXISTING		REGISTER #5		500						
6		20	EXISTING		REGISTER #7		500						
8		20	EXISTING		REGISTER #3		500						
10		20	EXISTING		REGISTER #2		500						
12		20			SPARE								
14		20	EXISTING		REGISTER #1		500						
16		20	EXISTING		VENDING			1200					
18		20	EXISTING		VENDING			1200					
20		20	EXISTING		DOOR OPENER								600
22		20	EXISTING		DOOR OPENER								600
24		20	EXISTING		DOOR OPENER								600
26		20	2#10+1#10GRD	3/4	GE186			1680					
28		20	2#10+1#10GRD	3/4	HDR2								1400
30		20	2#10+1#10GRD	3/4	HDR2								1400
32		20	2#10+1#10GRD	3/4	HDR2								1400
34		20	2#10+1#10GRD	3/4	HDR2								1400
36		20	2#10+1#10GRD	3/4	RESTROOM ACCESSORIES								1200
38		30	EXISTING		U-SCAN KYSOR CASE			1200					
40		20	EXISTING		REGISTER								
42		20	EXISTING		REGISTER								

CONNECTED LOAD (VA)	29190		SUBTOTAL (VA)	###	6910	10080	###	3600	###	###	8600
DEMAND LOAD (VA)	25662		DEMAND	1.25	1.00	0.65	1.00	1.00	1.25	1.00	1.00
DEMAND LOAD (A)	71		TOTAL (VA)	###	6910	6552	###	3600	###	###	8600

(EXISTING) RP-LJ

208Y/120V 400A BUS 3PH 4W MLO – SURFACE

POLE	TYPE	TRIP	WIRE	CND	DESCRIPTION	LTG	RECP	KIT	SPC HEAT	SPC COOL	HTRS	ELEV	MISC
1								1200					
3		20	EXISTING		DELI HOT CASE			1200					
5								1200					
7		20											
9		20	2#10+1#10GRD	3/4	D1DSC4HP			1032					
11		20	2#10+1#10GRD	3/4	D1DSC4HP			1032					
13		20	2#10+1#10GRD	3/4	D1DSC4HP			1032					
15		20	2#10+1#10GRD	3/4	D1DSC4HP			1032					
17								528					
19		20	EXISTING		RIGHT OVEN			528					
21								528					
23								528					
25		20	EXISTING		LEFT OVEN			528					
27								528					
29													
31		20	EXISTING										
33													
35		20											
37		20	EXISTING		RIGHT OVEN			1200					
39		20	EXISTING		LEFT OVEN			1200					
41		20											
2		20	EXISTING		OLIVE BAR DROP CORD			1200					
4		20											
6		20											
8													
10		30	EXISTING		KYSOR CASE DROP CORD			1800					
12		30	EXISTING		BERRY CASES BAKERY			1800					
14								1800					
16													
18		20	EXISTING		COLD CASE CORD DROP			1200					
20		20											
22		20	EXISTING		UNDER FLOOR HEAT TRACE						1200		
24		20	EXISTING		DOOR WARMER						1200		
26		20	EXISTING		CONDENSATE HEAT TRACE						1200		
28		20											
30		20											
32		20											
34		20											
36		20											
38		20											
40		20											
42													

CONNECTED LOAD (VA)	24696		SUBTOTAL (VA)	####	#####	21096	####	####	3600	##	####
DEMAND LOAD (VA)	18212		DEMAND	1.25	1.00	0.65	1.00	1.00	1.25	1.00	1.00
DEMAND LOAD (A)	51		TOTAL (VA)	####	####	13712	####	####	4500	##	####

(EXISTING) LP-HC

480Y/277V 100A BUS 3PH 4W MLO – SURFACE

POLE	TYPE	TRIP	WIRE	CND	DESCRIPTION	LTG	RECP	KIT	SPC HEAT	SPC COOL	HTRS	ELEV	MISC
1		50	EXISTING	–	PARKING LOT	6000							
3						6000							
5		50	EXISTING	–	PARKING LOT	6000							
7						6000							
9		20	EXISTING	–	PARKING LOT	2770							
11		20	EXISTING	–	PARKING LOT	2770							
13		20	–	–	SPARE								
15		20	–	–	SPARE								
17		20	–	–	SPARE								
19		20	–	–	SPARE								
21		20	–	–	SPARE								
23		20	–	–	SPARE								
25		20	–	–	SPARE								
27		20	–	–	SPARE								
29		20	–	–	SPARE								
31		20	–	–	SPARE								
33		20	–	–	SPARE								
35		20	–	–	SPARE								
37		20	–	–	SPARE								
39		20	–	–	SPARE								
41		20	–	–	SPARE								
2		20	EXISTING	–	EXT LIGHTS	2770							
4		20	EXISTING	–	EXT LIGHTS	2770							
6		20	EXISTING	–	EXT LIGHTS	2770							
8		20	EXISTING	–	EXT LIGHTS	2770							
10		20	EXISTING	–	EXT LIGHTS	2770							
12		20	EXISTING	–	EXT LIGHTS	2770							
14		20	EXISTING	–	EXT LIGHTS	2770							
16		20	EXISTING	–	STARBUCKS COFFEE SIGNS	1200							
18		20	EXISTING	–	STARBUCKS COFFEE SIGNS	1200							
20		20	EXISTING	–	WALLPACKS NW	2770							
22		20	EXISTING	–	WALLPACKS NW	2770							
24		20	2#10+1#10GRD	3/4	PICKUP SIGN	1200							
26		20	–	–	SPARE								
28		20	–	–	SPARE								
30		20	EXISTING	–	PHARMACY SIGN	1200							
32		20	–	–	SPARE								
34		20	–	–	SPARE								
36		20	–	–	SPARE								
38		20	–	–	SPARE								
40		20	–	–	SPARE								
42		20	–	–	SPARE								

CONNECTED LOAD (VA)	59270		SUBTOTAL (VA)	59270	###	###	####	####	####	###	####
DEMAND LOAD (VA)	74088		DEMAND	1.25	1.00	0.90	1.00	1.00	1.25	1.00	1.00
DEMAND LOAD (A)	89		TOTAL (VA)	74088	###	####	####	####	####	###	####

issued for: BIDS AND PERMITS 02/27/2024
90% OWNER REVIEW 01/11/2024

PROPOSED MINOR INTERIOR REMODEL FOR:

Kroger

STORE NO. D-707

2010 WITTAKER ROAD
YPSILANTI, MI 48197

THE KROGER CO. OF MICHIGAN

jeffery a. scott architects p.c.

32316 grand river ave. suite 200
farmington, michigan 48336-3261
(248) 476-8800 fax (248) 476-8833

PANEL SCHEDULES

project no. 23044

sheet no. E6.2.2

PLOT FULL SIZE @ 30"x42"

copyright © 2024