




MECHANICAL GENERAL NOTES:

- ALL FEDERAL, STATE, LOCAL, AND OSHA SAFETY RULES MUST BE OBSERVED.
- LOCATE ALL HVAC TEMPERATURE ROOM SENSORS, AND CONTROL PANELS 60" ABOVE FINISHED FLOOR. ALL TEMP SENSORS FOR HVAC SYSTEM ARE TIED BACK TO THE CONTROLLER.
- CONTRACTOR MUST PROVIDE COMPLETE SHOP DRAWINGS INDICATING ALL CONTROL WIRING, SYSTEM COMPONENTS, COMPONENT MANUFACTURER AND APPLIED SEQUENCE OF OPERATIONS FOR ALL SYSTEM FOR REVIEW BEFORE PURCHASE OF EQUIPMENT OR INSTALLATION. WIRING SHALL BE INSTALLED PER DIV 26 SPECIFICATIONS.
- PROVIDE CONDENSATE DRAINS FOR ALL NEW HVAC UNITS. DISCHARGE DRAIN FOR SPLIT SYSTEMS FROM CONDENSATE PUMP UP THROUGH ROOF AND SPILL ONTO ROOF.
- FIELD VERIFY ALL EXISTING MECHANICAL SYSTEMS AND EQUIPMENT. REPORT DISCREPANCIES BETWEEN FIELD CONDITIONS AND CONTRACT DOCUMENTS TO KROGER MECHANICAL ENGINEER FOR DIRECTION PRIOR TO COMMENCING WORK.
- CONTRACTOR SHALL COORDINATE LOCATION OF ALL EQUIPMENT AND SYSTEMS WITH EXISTING CONDITIONS AND OTHER TRADES TO AVOID AND RESOLVE CONFLICT.
- HVAC BUILD PLAN SHOWN WITH RESPECT TO NEW STORE FIXTURE LAYOUT FOR CLARITY.
- ALL OVEN EXHAUST FANS AND KITCHEN HOODS TO BE WIRED WITH ELECTRICAL INTERLOCKS SO THAT THE EQUIPMENT WILL NOT TURN ON UNLESS THE EXHAUST FAN IS WORKING AND FUNCTIONAL. SEE ELECTRICAL SHEETS FOR MORE DETAILS.
- START-UP TO BE DONE WITH KROGER MECHANICS PRESENT.
- ALL NEW HVAC UNITS TO BE INSTALLED LEVEL. HVAC CONTRACTOR TO PROVIDE ALL ROOF WORK TO ENSURE THAT NEW UNITS ARE LEVEL. PROVIDE CONDENSATE PIPING PER LOCAL CODES.



SPLIT-SYSTEM COOLING ONLY UNIT SCHEDULE														
MARK	SERVICE	MODEL NO.	FAN		COOLING				ELECTRICAL			MOUNTING	WEIGHT (LB)	REMARKS
			AIRFLOW (MIN/MAX CFM)	MOTOR FLA	CAPACITY (MBH)	REFRIGERANT TYPE	EFFICIENCY EER	SEER	VOLT/PHASE	MCA	MOCP			
FC-1	PICKUP (INDOOR UNIT)	TPLA0A0421EA70A	700-1200	0.95	42.0	R-410A	11.6	21	208-230/1	2	-	OPEN CEILING	56	1, 2, 3
AC-1	FC-1 (OUTDOOR UNIT)	TRUYA0421KA70NA	-	1.0						25	40	ROOF	211	
NOTES:														
1. MANUFACTURER'S OUTDOOR ELECTRIC RANGING HVAC SENSOR PANEL SHALL BE INSTALLED.														
2. PROVIDE WITH BASKET AND MODBUS INTERFACE (PAC-001R001-CN-11) CONNECT TO BUILDING MANAGEMENT SYSTEM														
3. PROVIDE WITH FIELD WIRED DISCONNECT BY ELECTRICAL, WIRELESS CONTROLLER AND MOUNT, FRONT WIND BAFFLE, CONDENSATE PUMP (X87-721) RATED 33 FT MAXIMUM DISCHARGE HEAD. PROVIDE WITH 30 FT TWIN TUBE LINESET (MPLS385812T-30). FIELD VERIFY EXACT ROUTING TO CONFIRM LINESET SIZE.														



ADDENDUM NO. 1  
BIDS AND PERMITS  
DIRECT BUY QUOTE  
90% OWNER REVIEW

03/18/2024  
03/08/2024  
02/18/2024  
01/25/2024

ISSUED FOR:

PROPOSED MINOR INTERIOR  
REMODEL FOR:

**Kroger**

STORE NO. D-711  
7084 MILLER ROAD  
SWARTZ CREEK, MI 48473

THE KROGER CO. OF MICHIGAN

**jeffery a. scott architects p.c.**

32316 grand river ave. suite 200  
farmington, michigan 48336-3261  
(248) 476-8800 fax (248) 476-8833

MECHANICAL PLAN

project no. 23086  
sheet no. M1:1

copyright © 2024