

MEZZANINE PLAN
SCALE: 3/32" = 1'-0"

LIGHTING PLAN
SCALE: 3/32" = 1'-0"

- ### GENERAL NOTES
- COORDINATE SCHEDULING WITH KROGER ENGINEER. REFER TO SHEET G1.1.
 - REUSE EXISTING BRANCH CIRCUITS MADE AVAILABLE BY DEMOLITION WHERE PRACTICABLE UNLESS NOTED OTHERWISE. EXTEND EXISTING WIRING METHODS AS REQUIRED TO ACCOMMODATE NEW EQUIPMENT LOCATIONS. PROVIDE ADJUSTMENTS OR ADDITIONAL BRANCH CIRCUITS AS REQUIRED FROM NEAREST SUITABLE PANELBOARD. ROUTE NEW RACEWAYS BY MOST PRACTICAL CONCEALED MEANS AVAILABLE UNLESS NOTED OTHERWISE. DO NOT INSTALL EXPOSED RACEWAYS OR SCAUT WITHOUT THE CONSENT OF THE KROGER ENGINEER.
 - UPDATE AND PRINT LABELS AND DIRECTORIES FOR BRANCH CIRCUITS AFFECTED BY NEW CONSTRUCTION. DO NOT PROVIDE HANDWRITTEN IDENTIFICATION.
 - COORDINATE AND GROUP TOGETHER ALL PIPE DROPS IN SALES AREA FROM ROOF TO LOW WALLS OR EQUIPMENT WITH OTHER MECHANICAL PIPES.
 - PROVIDE (3) 120/30/1 BRANCH CIRCUITS FOR BOOK RACK LIGHTING AT LOCATIONS TO BE DETERMINED BY KROGER ENGINEER. FIELD VERIFY SOURCE. PROVIDE 30A/4P CONTACTOR TO SWITCH BRANCH CIRCUITS. WIRE CONTACTOR TO BUILDING MANAGEMENT SYSTEM.
 - PROVIDE (3) 120/30/1 BRANCH CIRCUITS FOR MAGAZINE RACK LIGHTING AT LOCATIONS TO BE DETERMINED BY KROGER ENGINEER. FIELD VERIFY SOURCE. PROVIDE 30A/4P CONTACTOR TO SWITCH BRANCH CIRCUITS. WIRE CONTACTOR TO BUILDING MANAGEMENT SYSTEM.
 - PROVIDE (3) 120/30/1 BRANCH CIRCUITS FOR GREETING CARD RACK LIGHTING AT LOCATIONS TO BE DETERMINED BY KROGER ENGINEER.
 - FIELD VERIFY SOURCE. PROVIDE 30A/4P CONTACTOR TO SWITCH BRANCH CIRCUITS. WIRE CONTACTOR TO BUILDING MANAGEMENT SYSTEM.
 - PROVIDE (3) 120/30/1 BRANCH CIRCUITS FOR COMMERCIAL OVEN BREAD AND COSMETICS RACK CANOPY LIGHTING AT LOCATIONS TO BE DETERMINED BY KROGER ENGINEER. FIELD VERIFY SOURCE. PROVIDE 30A/4P CONTACTOR TO SWITCH BRANCH CIRCUITS. WIRE CONTACTOR TO BUILDING MANAGEMENT SYSTEM.
 - NOT USED.
 - INSTALL DOCK AND BACKROOM LIGHTING LUMINAIRES AS HIGH AS PRACTICABLE BETWEEN BAR JOISTS TO PROTECT FROM DAMAGE.
 - INSTALL PREP ROOM LIGHTING RACEWAY ON TOP OF INSULATED ROOF PANEL AND STUB THROUGH PANEL INTO LUMINAIRES.
 - PAINT WIRING AND SUPPORTING METHODS FOR ALL SUSPENDED LUMINAIRES TO MATCH EXPOSED STRUCTURE.
 - PRIORITIZE QUEVISION SENSING DEVICE LOCATIONS OVER THE INTERIOR LIGHTING PATTERN. WHERE INTERFERENCE OCCURS, ADJUST THE LIGHTING PATTERN AS REQUIRED TO ACCOMMODATE THE REQUIREMENTS OF THE QUEVISION SENSING DEVICES AT NO ADDITIONAL COST. COORDINATE ALL ADJUSTMENTS WITH THE QUEVISION INSTALLATION REPRESENTATIVE AND THE KROGER PROJECT MANAGER.
 - CLEAN ALL STORE LUMINAIRES.
 - REPAIR OR REPLACE DAMAGED OR INOPERATIVE LUMINAIRES (NORMAL, EMERGENCY, AND EXIT).
 - INSTALL NEW LAMPS FURNISHED BY KROGER IN ALL NEW STORE LUMINAIRES.
 - KROGER SHALL RELAMP ALL EXISTING OR RELOCATED LUMINAIRES.
 - REFER TO REFLECTED CEILING PLAN.
 - REFER TO LUMINAIRE SCHEDULE ON SHEET E6.2.4.
 - REFER TO PANEL SCHEDULES ON SHEETS E6.2.X FOR CONTACTOR CONTROL.
 - REFER TO A-SERIES SHEETS FOR ADDITIONAL REQUIREMENTS.
 - REFER TO DECOR I-SERIES SHEETS FOR ADDITIONAL REQUIREMENTS.
 - REPLACE ALL EXISTING EMERGENCY FLUORESCENT BALLASTS AND EMERGENCY LIGHTING UNIT EQUIPMENT WITH NEW EMERGENCY FLUORESCENT BALLASTS AND EMERGENCY LIGHTING UNIT EQUIPMENT.
 - FURNISH TRACK CURRENT LIMITERS. REFER TO KROGER TRACK CURRENT LIMITER MATRIX.
 - NOT USED.

PROVIDE RELOCATED WIRING METHODS AND DEVICES AS REQUIRED FOR VALANCE LIGHTS. (TYPICAL)

PROVIDE RELOCATED WIRING METHODS AND DEVICES AS REQUIRED. (TYPICAL)


EXTEND EXISTING WIRING METHODS AS REQUIRED.

PROVIDE RELOCATED WIRING METHODS AND DEVICES AS REQUIRED. (TYPICAL)

BIDS AND PERMITS
90% OWNER REVIEW

01/12/2024
12/14/2023

PROPOSED MINOR INTERIOR
REMODEL FOR:


STORE NO. D-715
1215 24TH ST
PORT HURON, MI 48060

THE KROGER CO. OF MICHIGAN



jeffery a.
scott
architects p.c.

32316 grand river ave. suite 200
farmington, michigan 48336-3261
(248) 476-8800 fax (248) 476-8833

LIGHTING PLAN

project no.
23085

sheet no.
E1.1

issued for:

01/12/2024
12/14/2023

copyright © 2024