




KEY NOTE	DESCRIPTION	WIRE TYPE ALL WIRING - PLENUM RATED
①	MAIN CONNECTION	BELDEN MT00A K24 9 CATEGORY-3E CABLE OR APPROVED EQUAL
②	EGEHLON NETWORK	WIRNY CITY 405500-0-5 K22-2 UNSHIELDED, THISTED CABLE OR APPROVED EQUAL
③	ANALOG / DIGITAL TEMPERATURE SENSOR / INPUT	BELDEN R02700 R0-2 SHIELDED CABLE OR APPROVED EQUAL
④	DEFROST TERMINATION SENSOR	BELDEN R02700 R0-2 SHIELDED CABLE OR APPROVED EQUAL
⑤	RELATIVE HUMIDITY/TEMP SENSOR	BELDEN R02400 R0-4 SHIELDED CABLE OR APPROVED EQUAL
⑥	LIGHT LEVEL SENSOR / CO2 SENSOR	BELDEN R02400 R0-4 SHIELDED CABLE OR APPROVED EQUAL
⑦	LIGHTING CONTROL	R#4 THISTED PAIR PER LIGHTING CONTACTOR
⑧	REFRIGERATION SOLENOID VALVE	R#4 THISTED PAIR
⑨	HVAC STAGING CONTROL	2-W#10 MULTI-CONDUCTOR CABLE
⑩	UNIT HEATER CONTROL	R#4 THISTED PAIR
⑪	LINE VOLTAGE IN CONDUIT	PER NEG 4 MANUFACTURER'S GUIDELINES
⑫	0 - 10V SIGNAL	BELDEN R02700 R0-2 SHIELDED CABLE OR APPROVED EQUAL
⑬	DRIVE HEALTHY	BELDEN R02700 R0-2 SHIELDED CABLE OR APPROVED EQUAL
⑭	DRIVE ENABLE	BELDEN R02400 R0-4 SHIELDED CABLE OR APPROVED EQUAL
⑮	REFRIGERATION TRANSDUCER	BELDEN R02400 R0-4 SHIELDED CABLE OR APPROVED EQUAL

3	ENERGY MANAGEMENT WIRING SCHEDULE	SCALE: NONE	5
---	-----------------------------------	-------------	---



6	GENERAL SYMBOLS	SCALE: NONE
---	-----------------	-------------

- | | | |
|---|-------------------------|-------------|
| 7 | ENERGY MANAGEMENT NOTES | SCALE: NONE |
|---|-------------------------|-------------|

copyright © 2024