




1 BOX PROBE MOUNTING DETAIL SCALE: NONE



2 SENSOR INSTALLATION - COOLER BOX SCALE: NONE



3 CASE SENSOR LOCATIONS (MULTI-DECK) SCALE: NONE



4 CASE SENSOR LOCATIONS (SINGLE-DECK) SCALE: NONE

NOTES

ALL HVAC SENSORS (I.E. ANALOG TEMPERATURE SENSORS, RELATIVE HUMIDITY SENSORS, CO2 SENSORS) TO BE MOUNTED AT 7'-6" ABOVE FINISHED FLOOR.

LIGHTING OVERRIDE SWITCHES TO BE MOUNTED AT 6'-4" ABOVE FINISHED FLOOR.

- FOR REFERENCE ONLY -
CONSTRUCTION GUIDELINES

BIDS AND PERMITS
01/12/2024

ISSUED FOR:
90% OWNER REVIEW
12/14/2023

PROPOSED MINOR INTERIOR
REMODEL FOR:



STORE NO. D-715
1215 24TH ST
PORT HURON, MI 48060

THE KROGER CO. OF MICHIGAN



jeffery a.
scott
architects p.c.

32316 grand river ave. suite 200
farmington, michigan 48336-3261
(248) 476-8800 fax (248) 476-8833

ENERGY MGMT TERM DETAILS

project no. 23085 sheet no. EM-2C

copyright © 2024

plot full size @ 30"x42"